



Freedom of Information request reference number: 6731.1

Date of response: 08/08/2022

Request:

A copy of an LFB inspection carried out in 2018 at Oak Lodge Close, Stanmore, HA7 4QB.

Response:

The result of the audit for Flats 1-21 and 22-35 Oak Lodge Close, Stanmore, HA7 4QB confirmed that some fire safety matters require attention to reduce the risk of fire and/or reasonably ensure the safety of people using the premises and these matters need to be addressed in order to comply with Regulatory Reform (Fire Safety) Order 2005 (the Fire Safety Order). As a result, an informal notification of (fire safety) deficiencies (NOD) was issued for these premises. I have attached copies of the NODs below.

When issuing a NOD the expectation is that the issues are minor enough that they can be rectified without needing any formal intervention from the LFB (which is different to an Enforcement Notice). As such, it would be for the Responsible Person(s) of the premises to be satisfied the deficiencies noted are addressed appropriately and within the recommended time frame. The LFB will then check these issues when the property is visited at the next routine inspection (according to the level of risk).

The audit reports for Flats 1-21 and Flats 22-35 have been withheld. Where a Fire Safety audit results in a notice being issued by the LFB, the reports themselves are exempt from release under the FOIA provisions under Section 31 of the FOIA - law enforcement (Section 31(1)(g) combined with 31(2) (a) and 31(2) (c)).

When the LFB identifies any safety concerns, we make this information available to the public by supplying copies of any informal notification of fire safety deficiencies (NOD) issued, and through access to the public register of any formal enforcement action. We clearly understand that there is public interest and concern about knowing about the fire safety of the buildings in which people live, work or visit however we need to maintain a balance between the public interest in safety and the Brigade's ability to work with responsible persons in a safe space where honest, frank and meaningful discussions can take place.

It is important that enforcing authorities are assisted in their investigations if witnesses and those responsible for compliance with regulations are willing to cooperate with the investigation on a voluntary basis and investigators are able to take full contemporaneous notes (that are recorded on the audit forms) and enter in discussions (either verbally, or by correspondence) with those involved to enable them to explore all aspects of the case and then arrive at a decision as to the appropriate action to take.

We have dealt with your request under the Freedom of Information Act 2000. For more information about this process please see the guidance we publish about making a request on our website: https://www.london-fire.gov.uk/about-us/transparency/request-information-from-us/



Fire Safety Regulation, North West 3 Team 169 Union Street London SE1 OLL T 020 8555 1200

> Minicom london-fire.gov.uk

The London Fire Commissioner is the fire and rescue authority for London

Date 29 November 2021 Our Ref 29/236686/EB

John Whiteman & Co Llp C/O Hillier Hopkins Llp Radius House First Floor 51 Clarendon Road Watford Herts WD17 1HP

Dear Sir/Madam

REGULATORY REFORM (FIRE SAFETY) ORDER 2005: NOTIFICATION OF FIRE SAFETY DEFICIENCIES

Premises: Flats 1-21, Oak Lodge Close, Stanmore, HA7 4QB

The London Fire Commissioner (the Commissioner) is the fire and rescue authority for London. The Commissioner is responsible for enforcing the Regulatory Reform (Fire Safety) Order 2005 (The Order) in London.

The Commissioner's Inspectors have recently carried out an inspection of the above-mentioned premises. During the inspection, it was noted that some fire safety matters require attention to reduce the risk of fire and/or reasonably ensure the safety of people using the premises. These matters need to be addressed in order to comply with Regulatory Reform (Fire Safety) Order 2005 (the Fire Safety Order).

The matters that need to be addressed, together with the Commissioner's recommendations about the actions you should take are explained in the attached schedule. We recommend that action should be taken by **21 February 2022**.

If you are in any doubt about what you need to do to comply with the Fire Safety Order; or if there is anything in the schedule that you do not understand or need further explanation of then please contact the Inspector named at the end of this letter. If you are dissatisfied in any way with the response given please ask to speak to the Team Leader quoting the above reference.

You may also wish to know that fire safety guidance for businesses can be found on the Commissioner's web-site at www.london-fire.gov.uk under the heading 'Fire safety at work'. Additionally, guidance on general fire precautions and how to comply with the Fire Safety Order can be found at www.Gov.uk under the heading 'Fire safety law and guidance documents for business'.

When undertaking fire safety works at your premises you may need to seek approval for what you are going to do. Examples of this would include:

- any building works for which you are obliged to notify or seek the approval of Building Control;
- if your premises have a listed heritage status, approval from the local authority conservation officer; or
- if your premises are licenced then you may need to consult the relevant licensing or approvals authority.
- It is your responsibility to consult the relevant bodies and obtain any necessary approvals.

I would ask you to note that as well as placing people at risk, operating premises without having adequate general fire precaution in place to remove or reduce fire risk and to ensure people can safely escape if a fire does occurs can result in a criminal offence being committed. This letter and its associated schedule are consequently issued without prejudice to any legal action the Commissioner may subsequently take regarding failures to comply with the Fire Safety Order.

Yours faithfully,

Yours faithfully,

for Assistant Commissioner (Fire Safety)

Directorate of Operations FSR-AdminSupport@london-fire.gov.uk

Reply to Fire Safety Advisor Direct **T** 020 8555 1200

Enc: Form FS03_01b Legislation Extracts

Form FS03_06 Definitions of standard terms

Cc:

Notes to accompany the Notification of Deficiencies schedule.

Important information to consider before taking remedial steps:

- 1. Certain terms written in BLOCK CAPITALS in the attached schedule are standard terms defined in "Definitions of standard terms used in means of escape requirements" which form part of this schedule.
- 2. Officers of the Commissioner may visit your premises again to check on the action you have taken.
- 3. Notwithstanding any consultation undertaken by the Commissioner, before you make any alterations to the premises, you must apply for local authority building control department approval (and/or the approval of any other bodies having a statutory interest in the premises) if their permission is required for those alterations to be made.
- 4. There may be suitable alternative safety measures to those detailed in this schedule, which would meet the requirements of the Order. If you wish to propose or discuss any alternative measures you should get in touch with the person named as the contact above, before you take any action, to ensure that your proposed measures are deemed satisfactory by the Commissioner.
- 5. Remedial steps must be undertaken by a competent person who has sufficient training, experience, knowledge or other qualities to enable him or her to properly undertake them.
- 6. We recommend that remedial steps are undertaken in accordance with the appropriate British or European Standards, or recognised industry guidance.

THE REGULATORY REFORM (FIRE SAFETY) ORDER 2005

Your rights when Fire Safety Inspecting Officers take action.

The Commissioner has a duty to enforce the Regulatory Reform (Fire Safety) Order 2005.

If an Inspector:

tells you to do something - you have a right to a verbal and written explanation of what needs to be done and why.

Intends to take immediate action - for example by issuing an enforcement notice this will include a written explanation either forming part of the notice or by separate letter.

Issues a formal notice - you will be told in writing about your right to appeal to a magistrates' court. You will be told:

- ♦ how to appeal;
- where and within what period an appeal may be brought; and
- that action required by a prohibition/restriction notice is not suspended while an appeal is pending unless the court so directs.
- that action required by an enforcement notice is suspended while an appeal is pending.

Issues a Notification of Fire Safety Deficiencies - <u>full discussion should have taken place and agreed</u> <u>improvements to bring the premises up to minimal standards should be formulated</u>. A Notification

of Fire Safety Deficiencies carries no statutory force but may result in formal action being considered if the agreed improvements do not take place.

The procedures and rights above provide ways for you to have your views heard. If you are not happy with the inspecting officer's action you should contact the Team Leader on the telephone number shown at the head of the covering letter in the first instance.

ENVIRONMENT AND SAFETY INFORMATION ACT 1988 SECTION 4 - PROTECTION OF TRADE SECRETS

The above Act requires the London Fire Commissioner to maintain public registers of notices issued under Article 30 of the Regulatory Reform (Fire Safety) Order 2005, (other than those which impose requirements or prohibitions solely for the protection of persons at work) and Sections 21 and 22 of the Health and Safety at Work etc, Act 1974.

Provisions are made within the Act for persons on whom the above notices are served to appeal against any proposed entry in the register which may disclose "trade secrets" or "secret manufacturing processes".

Entries in the register are required to be made after the period for appeal against the notice expires or after any appeal is disposed of.

If you feel that any such entry would disclose information about a trade secret or secret manufacturing process you may write to the Commissioner within a period of 14 days following the service of the notice, requesting exclusion of these details (see Section 4 of the 1988 Act).

SCHEDULE

PREMISES: Flats 1-21, Oak Lodge Close, Stanmore, HA7 4QB

FILE NUMBER: 29/236686

This schedule should be read in conjunction with the Commissioner's letter dated **29 November 2021**.

The condition(s) specified in the Regulatory Reform (Fire Safety) Order 2005, were being contravened and the following step(s) need(s) to be taken in order to comply with the above legislation:

Article	Area of Concern	Steps Considered necessary to remedy the contravention.
Article 11	At the time of the audit your preventative and protective measures had not been planned, organised, controlled, monitored or reviewed where required. It was found that there were a number of significant findings in the fire risk assessment carried out in 2018. A number of which were still evident at the time of my inspection, which demonstrates a failure to review the significant findings and in turn plan, organise, control and monitor the recommendations of each finding.	Arrangements identified as not suitably addressed must be effectively planned, organised, controlled, monitored or reviewed.
Article 14	At the time of the audit the emergency routes or exits were inadequate. It was found that a number of doors did not self close sufficiently into their frames and did not have intumescent strips or cold smoke seals.	Ensure adequate emergency routes and exits, for use by relevant persons in the premises, are available and can be safely and effectively used at all relevant times. This can be achieved by contracting a competent person to carry out a survey of the doors and carry out the necessary remedial works to bring them up to the required standard.
Article 14	At the time of the audit the emergency routes or exits were inadequate. It was found that the rubber seals on the bin chute had either perished or were missing.	Ensure adequate emergency routes and exits, for use by relevant persons in the premises, are available and can be safely and effectively used at all relevant times. This can be achieved by contracting a competent person to fit new rubber seals to the bin chute.

Article 17	At the time of the audit you	Arrange initial and ongoing maintenance ensuring
	had not ensured that a suitable	fire safety measures are kept in an efficient state,
	system of maintenance was in	working order and good repair. This can be achieved
	place in your premises.	by appointing a competent person to carry out
		weekly and 6 monthly testing and maintenance and
	1)It was found that the	keeping a record of this.
	emergency escape lighting was	
	not subject to 6 monthly	
	preventative and protective	
	maintenance.	
	2)The weekly testing of the	
	emergency escape lighting is	
	not recorded.	
Article 9	At the time of the audit the fire	The fire risk assessment should be reviewed.
	risk assessment for your	
	premises has not been subject	
	to a suitable system of review.	
	It was found that the fire risk	
	assessment carried out in	
	January 2018 has not been	
	subject to an annual review as	
	per the recommendation of the	
	fire risk assessment.	

RECOMMENDATIONS NOT FORMING REQUIREMENTS OF THE SCHEDULE

The Commissioner would strongly urge that you consider the presence of combustible façade cladding materials as part of the risk assessment process for these premises. All relevant information about any replacement window and facade schemes should be made fully available to fire risk assessors. Where no reliable information is available for a given property, a strategy to assess the risk and where necessary implement short, medium and long term actions to address the risk should be implemented.

Where remedial measures are to be undertaken to which consultation requirements under Section 20 of the Landlord and Tenant Act 1985 will apply, the Commissioner would urge you to consider application of the disapplication provisions under Section 20ZA of that Act.



Fire Safety Regulation, North West 3 Team 169 Union Street London SE1 OLL T 020 8555 1200

> Minicom london-fire.gov.uk

The London Fire Commissioner is the fire and rescue authority for London

Date 29 November 2021 Our Ref 29/255905/EB

FW Lettings Limited 62-64 High Road Bushey Heath Bushey Hertfordshire WD23 1GG

Dear Sir/Madam

REGULATORY REFORM (FIRE SAFETY) ORDER 2005: NOTIFICATION OF FIRE SAFETY DEFICIENCIES

Premises: Flats 22-35, Oak Lodge Close, Stanmore, HA7 4QB

The London Fire Commissioner (the Commissioner) is the fire and rescue authority for London. The Commissioner is responsible for enforcing the Regulatory Reform (Fire Safety) Order 2005 (The Order) in London.

The Commissioner's Inspectors have recently carried out an inspection of the above-mentioned premises. During the inspection, it was noted that some fire safety matters require attention to reduce the risk of fire and/or reasonably ensure the safety of people using the premises. These matters need to be addressed in order to comply with Regulatory Reform (Fire Safety) Order 2005 (the Fire Safety Order).

The matters that need to be addressed, together with the Commissioner's recommendations about the actions you should take are explained in the attached schedule. We recommend that action should be taken by **21 February 2022**.

If you are in any doubt about what you need to do to comply with the Fire Safety Order; or if there is anything in the schedule that you do not understand or need further explanation of then please contact the Inspector named at the end of this letter. If you are dissatisfied in any way with the response given please ask to speak to the Team Leader quoting the above reference.

You may also wish to know that fire safety guidance for businesses can be found on the Commissioner's web-site at www.london-fire.gov.uk under the heading 'Fire safety at work'. Additionally, guidance on general fire precautions and how to comply with the Fire Safety Order can be found at www.Gov.uk under the heading 'Fire safety law and guidance documents for business'.

When undertaking fire safety works at your premises you may need to seek approval for what you are going to do. Examples of this would include:

- any building works for which you are obliged to notify or seek the approval of Building Control;
- if your premises have a listed heritage status, approval from the local authority conservation officer; or
- if your premises are licenced then you may need to consult the relevant licensing or approvals authority.
- It is your responsibility to consult the relevant bodies and obtain any necessary approvals.

I would ask you to note that as well as placing people at risk, operating premises without having adequate general fire precaution in place to remove or reduce fire risk and to ensure people can safely escape if a fire does occurs can result in a criminal offence being committed. This letter and its associated schedule are consequently issued without prejudice to any legal action the Commissioner may subsequently take regarding failures to comply with the Fire Safety Order.

Yours faithfully,

for Assistant Commissioner (Fire Safety)

Directorate of Operations FSR-AdminSupport@london-fire.gov.uk

Reply to Fire Safety Advisor Direct **T** 020 8555 1200

Enc: Form FS03_01b Legislation Extracts

Form FS03_06 Definitions of standard terms

Cc:

Notes to accompany the Notification of Deficiencies schedule.

Important information to consider before taking remedial steps:

- 1. Certain terms written in BLOCK CAPITALS in the attached schedule are standard terms defined in "Definitions of standard terms used in means of escape requirements" which form part of this schedule.
- 2. Officers of the Commissioner may visit your premises again to check on the action you have taken.
- 3. Notwithstanding any consultation undertaken by the Commissioner, before you make any alterations to the premises, you must apply for local authority building control department approval (and/or the approval of any other bodies having a statutory interest in the premises) if their permission is required for those alterations to be made.
- 4. There may be suitable alternative safety measures to those detailed in this schedule, which would meet the requirements of the Order. If you wish to propose or discuss any alternative measures you should get in touch with the person named as the contact above, before you take any action, to ensure that your proposed measures are deemed satisfactory by the Commissioner.
- 5. Remedial steps must be undertaken by a competent person who has sufficient training, experience, knowledge or other qualities to enable him or her to properly undertake them.
- 6. We recommend that remedial steps are undertaken in accordance with the appropriate British or European Standards, or recognised industry guidance.

THE REGULATORY REFORM (FIRE SAFETY) ORDER 2005

Your rights when Fire Safety Inspecting Officers take action.

The Commissioner has a duty to enforce the Regulatory Reform (Fire Safety) Order 2005.

If an Inspector:

tells you to do something - you have a right to a verbal and written explanation of what needs to be done and why.

Intends to take immediate action - for example by issuing an enforcement notice this will include a written explanation either forming part of the notice or by separate letter.

Issues a formal notice - you will be told in writing about your right to appeal to a magistrates' court. You will be told:

- how to appeal;
- where and within what period an appeal may be brought; and
- that action required by a prohibition/restriction notice is not suspended while an appeal is pending unless the court so directs.
- that action required by an enforcement notice is suspended while an appeal is pending.

Issues a Notification of Fire Safety Deficiencies - <u>full discussion should have taken place and agreed</u> <u>improvements to bring the premises up to minimal standards should be formulated</u>. A Notification

of Fire Safety Deficiencies carries no statutory force but may result in formal action being considered if the agreed improvements do not take place.

The procedures and rights above provide ways for you to have your views heard. If you are not happy with the inspecting officer's action you should contact the Team Leader on the telephone number shown at the head of the covering letter in the first instance.

ENVIRONMENT AND SAFETY INFORMATION ACT 1988 SECTION 4 - PROTECTION OF TRADE SECRETS

The above Act requires the London Fire Commissioner to maintain public registers of notices issued under Article 30 of the Regulatory Reform (Fire Safety) Order 2005, (other than those which impose requirements or prohibitions solely for the protection of persons at work) and Sections 21 and 22 of the Health and Safety at Work etc, Act 1974.

Provisions are made within the Act for persons on whom the above notices are served to appeal against any proposed entry in the register which may disclose "trade secrets" or "secret manufacturing processes".

Entries in the register are required to be made after the period for appeal against the notice expires or after any appeal is disposed of.

If you feel that any such entry would disclose information about a trade secret or secret manufacturing process you may write to the Commissioner within a period of 14 days following the service of the notice, requesting exclusion of these details (see Section 4 of the 1988 Act).

SCHEDULE

PREMISES: Flats 22-35, Oak Lodge Close, Stanmore, HA7 4QB

FILE NUMBER: 29/255905

This schedule should be read in conjunction with the Commissioner's letter dated **29 November 2021**.

The condition(s) specified in the Regulatory Reform (Fire Safety) Order 2005, were being contravened and the following step(s) need(s) to be taken in order to comply with the above legislation:

Article	Area of Concern	Steps Considered necessary to remedy the contravention.
Article 11	At the time of the audit your preventative and protective measures had not been planned, organised, controlled, monitored or reviewed where required. It was found that there were a number of significant findings in the fire risk assessment carried out in 2018. A number of which were still evident at the time of my inspection which demonstrates a failure to review the significant findings and in turn plan, organise, control and monitor the recommendations of each finding.	Arrangements identified as not suitably addressed must be effectively planned, organised, controlled, monitored or reviewed.
Article 14	At the time of the audit the emergency routes or exits were inadequate. It was found that: 1)The fire doors were missing intumescent strips and cold smoke seals. 2)It was found that some fire doors did not self close sufficiently into their frame.	Ensure adequate emergency routes and exits, for use by relevant persons in the premises, are available and can be safely and effectively used at all relevant times. This can be achieved by carrying out regular checks of the fire doors and appointing a competent person to undertake any relevant remedial works to ensure the doors are compliant.
Article 17	At the time of the audit you had not ensured that a suitable system of maintenance was in place in your premises. It was found that:	Arrange initial and ongoing maintenance ensuring fire safety measures are kept in an efficient state, working order and good repair. This can be achieved by:

Article 9	At the time of the audit the fire risk assessment for your premises has not been subject to a suitable system of review. It was found that the fire risk assessment carried out in January 2018 has not been subject to an annual review as per the recommendation of the fire risk assessment.	The fire risk assessment should be reviewed.
	1)There is no 6 monthly preventative and protective maintenance in place for the emergency lighting system nor any records kept of the weekly internal testing.	1)Appointing a competent person to undertake 6 monthly preventative and protective maintenance of the emergency lighting system and keeping records of this and the weekly internal testing.

RECOMMENDATIONS NOT FORMING REQUIREMENTS OF THE SCHEDULE

The Commissioner would strongly urge that you consider the presence of combustible façade cladding materials as part of the risk assessment process for these premises. All relevant information about any replacement window and facade schemes should be made fully available to fire risk assessors. Where no reliable information is available for a given property, a strategy to assess the risk and where necessary implement short, medium and long term actions to address the risk should be implemented.

Where remedial measures are to be undertaken to which consultation requirements under Section 20 of the Landlord and Tenant Act 1985 will apply, the Commissioner would urge you to consider application of the disapplication provisions under Section 20ZA of that Act.