



LONDON FIRE BRIGADE

London Fire Brigade Headquarters  
169 Union Street London SE1 0LL  
T 020 8555 1200 F 020 7960 3602  
Textphone 020 7960 3629  
london-fire.gov.uk

**Freedom of Information request reference number:** 7358.1

**Date of response:** 27<sup>th</sup> April 2023

**Request:**

I'm working with the NHS on redrafting parts of the Firecode. One of these is 05-03 parts B and H.

We were asked to combine parts B and H into one document. This came from initial stakeholder engagement. We have done this but kept the design element separate from the false alarm stuff. I'm the existing part H there is data on the location of, and types of false alarm info. I've not been able to find updated data to this level of detail. The Home office data doesn't seem to go into that level of granularity. NHS are unable to provide this either. Are there any other sources that are available that you are aware of?

Please see below email communication I have had with the Data team following a request for data on Unwanted Fire Signals at Hospitals as part of a review of Hospital Fire Safety Guidance Documents.

I have attached a document that is currently being reviewed. The company contracted to complete the review on behalf of NHS are looking to update some of the figures given (See section 3 - Page 8-12 (or pages 17-21 if you go by the pdf page count)). This document will then be merged with another that is part of the same series.

**Response:**

The Excel spreadsheet attached details all false alarms that took place at hospitals where LFB were called to a fire between 2018 & 2022. This spreadsheet breaks down the false alarms attended into three different categories named Grandparent (top level), Parent (middle level) and child (bottom level). Some categories do not have a grandparent level, if this is the case the middle level will be repeated. An example of this is Malicious False Alarm.

Please see below the spreadsheet from Page 2 - 59.

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
01/01/2018 09:07:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/01/2018 18:26:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/01/2018 08:42:52	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
02/01/2018 18:25:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/01/2018 21:59:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/01/2018 22:00:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/01/2018 23:50:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
03/01/2018 00:20:45	Fire	Smoke/condensation	Steam	Hospital (P)
03/01/2018 06:49:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/01/2018 16:11:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/01/2018 20:24:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/01/2018 23:27:12	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
03/01/2018 23:54:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/01/2018 09:32:06	Fire	Smoke/condensation	Steam	Hospital (P)
04/01/2018 09:40:54	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
04/01/2018 13:15:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/01/2018 13:55:56	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/01/2018 16:18:57	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
05/01/2018 09:37:13	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/01/2018 10:14:34	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/01/2018 10:48:44	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
05/01/2018 19:36:40	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
05/01/2018 23:01:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/01/2018 04:18:45	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
06/01/2018 06:41:42	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
06/01/2018 12:20:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/01/2018 12:23:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/01/2018 17:55:35	Fire	Smoke/condensation	Steam	Hospital (P)
07/01/2018 14:26:55	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
07/01/2018 15:44:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/01/2018 00:23:52	Fire	Smoke/condensation	Smoking chimney	Hospital (P)
08/01/2018 09:02:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/01/2018 10:31:03	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/01/2018 07:51:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/01/2018 08:06:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/01/2018 15:44:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/01/2018 17:34:05	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
10/01/2018 18:48:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/01/2018 19:14:52	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/01/2018 02:15:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/01/2018 23:47:59	Fire	Smoke/condensation	Steam	Hospital (P)
12/01/2018 04:11:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/01/2018 09:37:04	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
12/01/2018 17:37:27	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
12/01/2018 18:55:34	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
12/01/2018 19:03:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/01/2018 00:40:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/01/2018 08:58:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/01/2018 09:19:06	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/01/2018 11:09:56	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/01/2018 21:05:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2018 00:55:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2018 18:21:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/01/2018 10:02:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/01/2018 10:45:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
15/01/2018 11:39:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/01/2018 17:44:04	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/01/2018 02:43:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/01/2018 09:30:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/01/2018 11:55:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/01/2018 12:58:22	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
17/01/2018 11:06:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/01/2018 16:17:33	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
17/01/2018 20:01:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/01/2018 20:39:54	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
18/01/2018 00:27:29	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
18/01/2018 08:23:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/01/2018 08:36:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/01/2018 11:18:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/01/2018 12:30:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/01/2018 15:31:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/01/2018 19:44:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/01/2018 23:55:50	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/01/2018 07:56:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/01/2018 18:26:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/01/2018 09:35:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
23/01/2018 00:29:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/01/2018 04:03:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/01/2018 12:03:52	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/01/2018 13:10:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/01/2018 16:54:11	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
24/01/2018 14:23:10	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/01/2018 15:57:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/01/2018 20:31:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/01/2018 22:29:38	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/01/2018 13:14:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/01/2018 13:14:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/01/2018 09:58:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/01/2018 13:53:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/01/2018 08:36:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/01/2018 09:12:48	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
27/01/2018 11:10:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/01/2018 15:03:31	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/01/2018 13:27:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/01/2018 12:55:41	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
29/01/2018 22:02:35	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/01/2018 09:20:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/01/2018 09:33:18	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/01/2018 13:30:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/01/2018 00:27:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/01/2018 08:41:33	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
31/01/2018 17:20:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
31/01/2018 23:07:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/02/2018 13:08:18	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
01/02/2018 14:01:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/02/2018 18:57:01	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
02/02/2018 13:17:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/02/2018 13:39:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/02/2018 20:15:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/02/2018 21:38:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/02/2018 06:17:10	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
03/02/2018 06:35:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/02/2018 16:49:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/02/2018 16:08:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/02/2018 21:10:44	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/02/2018 12:06:17	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
05/02/2018 15:41:30	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/02/2018 23:23:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/02/2018 01:18:03	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/02/2018 13:10:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/02/2018 18:59:04	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/02/2018 00:29:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
07/02/2018 10:35:37	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
07/02/2018 16:55:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/02/2018 19:58:24	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
08/02/2018 08:34:21	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
08/02/2018 12:33:12	Fire	Smoke/condensation	Water intrusion	Hospital (P)
09/02/2018 00:35:39	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
10/02/2018 12:16:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/02/2018 23:15:42	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/02/2018 05:28:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/02/2018 05:06:21	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/02/2018 09:54:37	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/02/2018 10:01:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/02/2018 11:02:09	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
13/02/2018 11:34:04	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/02/2018 11:49:27	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/02/2018 14:39:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/02/2018 15:26:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/02/2018 16:16:50	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
13/02/2018 19:18:06	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
14/02/2018 15:21:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/02/2018 16:51:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/02/2018 16:54:48	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
14/02/2018 17:38:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/02/2018 13:34:52	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/02/2018 11:17:03	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
17/02/2018 09:27:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/02/2018 11:43:40	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/02/2018 11:55:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/02/2018 12:39:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/02/2018 12:22:45	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
18/02/2018 13:45:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/02/2018 15:49:46	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
19/02/2018 08:44:38	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
19/02/2018 13:41:16	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
19/02/2018 16:45:35	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/02/2018 17:45:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/02/2018 20:07:43	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
20/02/2018 10:25:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/02/2018 16:55:21	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
21/02/2018 03:58:06	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
21/02/2018 09:20:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/02/2018 13:11:29	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/02/2018 17:29:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/02/2018 08:47:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/02/2018 16:04:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/02/2018 17:46:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
23/02/2018 09:59:23	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/02/2018 10:43:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/02/2018 17:41:17	Fire	Smoke/condensation	Steam	Hospital (P)
23/02/2018 19:25:04	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/02/2018 15:45:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/02/2018 15:51:06	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
24/02/2018 16:43:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/02/2018 16:46:15	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
24/02/2018 18:02:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/02/2018 18:53:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/02/2018 23:02:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/02/2018 09:13:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/02/2018 10:22:20	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
25/02/2018 23:11:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/02/2018 23:32:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2018 03:23:35	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/02/2018 08:04:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/02/2018 10:54:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2018 12:03:26	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
26/02/2018 13:48:42	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/02/2018 14:56:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/02/2018 17:34:19	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
26/02/2018 23:29:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/02/2018 03:03:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/02/2018 08:10:15	Fire	Smoke/condensation	Steam	Hospital (P)
27/02/2018 18:39:55	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/02/2018 19:44:16	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/02/2018 21:12:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/02/2018 06:51:43	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
28/02/2018 07:07:51	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/02/2018 07:42:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/02/2018 08:51:31	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
28/02/2018 17:54:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/03/2018 13:56:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/03/2018 15:26:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/03/2018 16:23:30	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/03/2018 17:40:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/03/2018 18:37:53	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
01/03/2018 18:58:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/03/2018 23:11:11	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/03/2018 06:43:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/03/2018 11:03:24	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
02/03/2018 16:18:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/03/2018 20:38:59	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
03/03/2018 04:03:04	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/03/2018 06:07:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/03/2018 10:24:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/03/2018 18:42:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/03/2018 05:45:48	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/03/2018 07:35:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/03/2018 09:26:34	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
04/03/2018 11:04:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/03/2018 11:50:59	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
04/03/2018 12:17:32	Fire alarm due to Apparatus	System: flame	Damaged system	Hospital (P)
04/03/2018 15:03:59	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
04/03/2018 15:14:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/03/2018 08:19:43	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
05/03/2018 09:30:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/03/2018 17:29:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/03/2018 10:43:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
06/03/2018 11:56:43	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/03/2018 14:33:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/03/2018 17:35:31	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/03/2018 22:22:21	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
07/03/2018 08:55:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/03/2018 11:12:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/03/2018 14:33:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/03/2018 21:34:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/03/2018 12:10:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/03/2018 17:06:53	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/03/2018 18:35:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/03/2018 01:21:48	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
09/03/2018 02:40:33	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/03/2018 09:54:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/03/2018 09:55:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/03/2018 10:20:51	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
09/03/2018 18:33:48	Fire alarm due to Apparatus	System: Animal	Fire alarm actuated accidentally by animal	Hospital (P)
10/03/2018 08:31:54	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
10/03/2018 08:56:38	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
10/03/2018 12:20:41	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/03/2018 13:59:49	Fire	Smoke/condensation	Steam	Hospital (P)
11/03/2018 01:08:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/03/2018 11:47:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/03/2018 13:33:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/03/2018 17:25:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/03/2018 00:18:21	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
13/03/2018 06:18:54	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
13/03/2018 12:12:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/03/2018 12:59:42	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/03/2018 14:08:00	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/03/2018 14:11:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/03/2018 18:43:28	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/03/2018 21:12:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/03/2018 01:19:35	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
14/03/2018 07:37:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/03/2018 10:55:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/03/2018 09:00:59	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
16/03/2018 18:03:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/03/2018 19:42:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/03/2018 20:31:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/03/2018 11:44:41	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
18/03/2018 18:31:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/03/2018 09:25:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/03/2018 11:14:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/03/2018 12:14:39	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
19/03/2018 19:09:05	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
19/03/2018 21:32:42	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
20/03/2018 07:53:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/03/2018 08:31:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
20/03/2018 13:09:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/03/2018 18:34:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/03/2018 15:56:20	Fire alarm due to Apparatus	System: heat	Alarm actuated - Other reason	Hospital (P)
21/03/2018 19:28:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/03/2018 01:33:59	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/03/2018 12:12:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/03/2018 17:07:49	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
23/03/2018 01:48:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/03/2018 08:18:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/03/2018 09:55:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/03/2018 15:07:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/03/2018 20:57:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/03/2018 09:12:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/03/2018 10:10:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/03/2018 02:26:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/03/2018 08:26:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/03/2018 14:51:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/03/2018 22:52:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/03/2018 00:12:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/03/2018 07:31:25	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/03/2018 10:36:12	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
28/03/2018 11:50:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/03/2018 13:30:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/03/2018 01:55:18	Fire	Smoke/condensation	Steam	Hospital (P)
30/03/2018 09:45:49	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/03/2018 11:16:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/03/2018 00:28:05	Fire	Burnt toast/food	Barbeque not out of control	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
31/03/2018 10:39:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/03/2018 12:02:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/03/2018 14:06:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/04/2018 10:55:33	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
01/04/2018 23:37:37	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
02/04/2018 00:36:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/04/2018 04:24:11	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
02/04/2018 11:52:38	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/04/2018 23:55:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/04/2018 10:05:31	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/04/2018 10:10:41	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/04/2018 11:07:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/04/2018 18:05:35	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/04/2018 13:43:08	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
05/04/2018 21:36:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/04/2018 11:32:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/04/2018 21:40:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2018 00:29:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/04/2018 02:24:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2018 08:18:15	Fire	Burnt toast/food	Barbeque not out of control	Hospital (P)
07/04/2018 10:30:45	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/04/2018 12:49:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/04/2018 20:10:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/04/2018 20:47:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2018 21:09:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/04/2018 03:12:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/04/2018 05:22:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/04/2018 08:48:54	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/04/2018 18:13:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/04/2018 19:17:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/04/2018 09:20:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/04/2018 11:10:08	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/04/2018 12:19:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/04/2018 19:12:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/04/2018 12:35:23	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/04/2018 07:56:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/04/2018 09:36:57	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/04/2018 12:40:58	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
12/04/2018 21:00:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/04/2018 08:52:38	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/04/2018 16:23:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/04/2018 08:44:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/04/2018 03:20:25	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/04/2018 13:42:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/04/2018 14:02:00	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
16/04/2018 17:17:33	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
17/04/2018 09:31:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/04/2018 13:33:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/04/2018 13:48:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/04/2018 17:14:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/04/2018 09:42:53	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
19/04/2018 19:40:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/04/2018 02:53:49	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
20/04/2018 08:36:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/04/2018 08:39:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/04/2018 15:31:29	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
20/04/2018 23:02:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/04/2018 02:06:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/04/2018 22:56:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/04/2018 01:30:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/04/2018 16:16:39	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
23/04/2018 16:35:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/04/2018 20:29:27	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
23/04/2018 20:53:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/04/2018 22:14:41	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/04/2018 11:44:53	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/04/2018 13:06:46	Fire alarm due to Apparatus	System: smoke alarm	Incorrect positioning	Hospital (P)
24/04/2018 14:03:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
24/04/2018 19:51:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2018 07:12:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2018 07:29:41	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/04/2018 08:00:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/04/2018 09:13:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2018 12:35:48	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
25/04/2018 13:59:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/04/2018 19:27:35	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
26/04/2018 03:43:11	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
26/04/2018 13:05:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/04/2018 17:39:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/04/2018 17:46:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/04/2018 08:09:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/04/2018 15:40:35	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/04/2018 18:53:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/04/2018 19:10:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/04/2018 23:43:24	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/04/2018 01:31:49	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/04/2018 01:55:54	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/04/2018 07:34:13	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/04/2018 09:43:55	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
28/04/2018 13:47:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/04/2018 20:35:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/04/2018 09:01:49	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
29/04/2018 10:28:48	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/04/2018 08:02:17	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
30/04/2018 08:39:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/04/2018 09:26:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/04/2018 21:17:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
30/04/2018 21:34:51	Fire alarm due to Apparatus	System: other	Unsuitable equipment	Hospital (P)
30/04/2018 22:35:01	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
30/04/2018 23:28:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/05/2018 13:14:38	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/05/2018 14:47:13	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
01/05/2018 15:15:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/05/2018 19:30:08	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
01/05/2018 20:00:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
01/05/2018 20:42:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/05/2018 18:43:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/05/2018 12:37:16	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
03/05/2018 14:16:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/05/2018 23:34:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/05/2018 06:41:31	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
04/05/2018 22:03:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/05/2018 23:08:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/05/2018 08:42:29	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/05/2018 10:01:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/05/2018 20:06:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/05/2018 20:07:15	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/05/2018 23:31:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/05/2018 08:12:12	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/05/2018 12:46:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/05/2018 14:09:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
08/05/2018 09:59:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/05/2018 10:26:11	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/05/2018 11:08:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/05/2018 17:37:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/05/2018 05:11:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/05/2018 09:50:00	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/05/2018 08:25:58	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/05/2018 14:18:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/05/2018 16:18:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2018 08:09:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2018 16:28:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/05/2018 16:42:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/05/2018 18:16:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2018 22:21:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/05/2018 11:52:57	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/05/2018 13:30:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/05/2018 09:22:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
14/05/2018 09:35:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/05/2018 11:09:08	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/05/2018 21:00:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/05/2018 09:18:59	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
15/05/2018 10:40:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/05/2018 12:47:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/05/2018 20:46:42	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/05/2018 21:33:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/05/2018 21:26:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/05/2018 23:10:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/05/2018 02:13:49	Fire	Smoke/condensation	Steam	Hospital (P)
21/05/2018 01:35:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/05/2018 05:29:03	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
21/05/2018 06:01:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
21/05/2018 06:12:24	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
21/05/2018 07:28:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/05/2018 15:03:56	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
23/05/2018 10:59:20	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
23/05/2018 14:38:15	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
23/05/2018 15:32:01	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/05/2018 23:35:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/05/2018 00:55:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/05/2018 03:22:23	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
24/05/2018 08:05:13	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
24/05/2018 11:13:38	Fire	Smoke/condensation	Steam	Hospital (P)
24/05/2018 15:08:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/05/2018 05:16:10	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
25/05/2018 22:35:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/05/2018 07:11:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/05/2018 17:02:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/05/2018 00:00:27	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
27/05/2018 08:38:51	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
27/05/2018 09:36:08	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
27/05/2018 15:10:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/05/2018 15:54:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/05/2018 22:55:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/05/2018 12:16:21	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
29/05/2018 10:52:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/05/2018 11:22:26	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/05/2018 00:16:29	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
30/05/2018 02:29:51	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
30/05/2018 03:57:34	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
30/05/2018 05:00:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/05/2018 09:49:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/05/2018 13:13:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/05/2018 06:59:55	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
31/05/2018 08:22:38	Fire alarm due to Apparatus	External Factors	Power surge	Hospital (P)
31/05/2018 10:02:55	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
31/05/2018 11:24:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
31/05/2018 18:16:25	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
01/06/2018 01:15:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/06/2018 05:27:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/06/2018 06:17:24	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
01/06/2018 07:59:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/06/2018 08:42:05	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
01/06/2018 15:52:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/06/2018 23:54:31	Fire	Smoke/condensation	Steam	Hospital (P)
02/06/2018 05:58:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/06/2018 10:46:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/06/2018 01:00:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/06/2018 09:38:38	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
04/06/2018 17:54:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/06/2018 21:05:51	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/06/2018 02:59:33	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/06/2018 10:28:51	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
05/06/2018 12:55:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/06/2018 18:48:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/06/2018 22:09:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
05/06/2018 22:13:21	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/06/2018 12:58:53	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/06/2018 05:36:05	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/06/2018 16:55:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/06/2018 09:35:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/06/2018 13:28:14	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/06/2018 13:47:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/06/2018 04:55:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/06/2018 03:19:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/06/2018 08:36:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/06/2018 14:15:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/06/2018 06:02:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/06/2018 06:40:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/06/2018 07:45:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/06/2018 08:48:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/06/2018 09:06:26	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/06/2018 09:31:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/06/2018 12:15:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/06/2018 14:44:36	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
11/06/2018 18:52:53	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
11/06/2018 20:42:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/06/2018 12:34:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
12/06/2018 15:22:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/06/2018 10:47:50	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
14/06/2018 10:24:47	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
14/06/2018 13:43:26	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/06/2018 17:10:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/06/2018 19:05:00	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
15/06/2018 15:16:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/06/2018 02:06:56	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/06/2018 18:03:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/06/2018 02:30:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/06/2018 20:30:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/06/2018 12:19:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/06/2018 14:04:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/06/2018 22:23:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/06/2018 09:28:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/06/2018 10:11:26	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
20/06/2018 12:20:55	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
20/06/2018 16:02:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/06/2018 19:26:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/06/2018 02:33:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/06/2018 10:58:12	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
22/06/2018 01:53:24	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/06/2018 14:28:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/06/2018 19:24:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
23/06/2018 01:19:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/06/2018 07:59:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/06/2018 14:08:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/06/2018 19:42:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/06/2018 05:51:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/06/2018 17:54:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/06/2018 03:42:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/06/2018 08:27:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/06/2018 12:07:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/06/2018 02:17:24	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/06/2018 10:17:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/06/2018 10:59:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/06/2018 12:19:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/06/2018 11:17:35	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/06/2018 11:48:21	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
27/06/2018 13:08:04	Fire alarm due to Apparatus	System: heat	Incorrect positioning	Hospital (P)
27/06/2018 14:40:24	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
27/06/2018 20:00:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/06/2018 20:03:50	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
28/06/2018 05:00:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/06/2018 07:48:20	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/06/2018 08:24:52	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/06/2018 18:32:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/06/2018 22:51:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/06/2018 07:48:34	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
30/06/2018 09:57:48	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/07/2018 01:04:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
01/07/2018 22:37:14	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
01/07/2018 23:46:28	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/07/2018 07:02:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/07/2018 10:07:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/07/2018 20:37:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
03/07/2018 00:32:54	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
03/07/2018 02:17:43	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
04/07/2018 14:19:32	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
04/07/2018 15:03:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/07/2018 21:35:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/07/2018 11:28:52	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
05/07/2018 12:08:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/07/2018 17:46:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/07/2018 21:12:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/07/2018 03:34:44	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
06/07/2018 08:51:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/07/2018 10:27:50	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/07/2018 18:32:13	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/07/2018 20:35:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/07/2018 21:12:24	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/07/2018 22:08:47	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
07/07/2018 23:28:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/07/2018 20:04:05	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
08/07/2018 20:14:36	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/07/2018 04:17:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
09/07/2018 11:27:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/07/2018 12:20:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/07/2018 19:25:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/07/2018 21:56:17	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
10/07/2018 10:37:24	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
11/07/2018 11:03:42	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
12/07/2018 00:36:18	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/07/2018 00:56:52	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/07/2018 12:39:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/07/2018 02:50:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/07/2018 04:13:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/07/2018 16:03:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2018 02:09:42	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/07/2018 03:41:01	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
14/07/2018 14:17:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
14/07/2018 16:12:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2018 17:13:28	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
14/07/2018 21:12:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/07/2018 09:15:34	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/07/2018 20:04:00	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/07/2018 03:07:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/07/2018 10:06:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/07/2018 11:29:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/07/2018 14:23:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/07/2018 02:19:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/07/2018 08:32:31	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/07/2018 10:33:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/07/2018 11:35:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/07/2018 18:17:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/07/2018 23:22:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/07/2018 01:48:36	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/07/2018 07:37:16	Fire	Burnt toast/food	Barbeque not out of control	Hospital (P)
19/07/2018 10:39:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/07/2018 01:20:09	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
21/07/2018 02:07:51	Fire	Burnt toast/food	Barbeque not out of control	Hospital (P)
21/07/2018 08:49:04	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/07/2018 10:19:27	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/07/2018 17:56:53	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/07/2018 20:06:04	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
22/07/2018 13:27:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/07/2018 21:04:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
23/07/2018 05:48:58	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/07/2018 06:09:40	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/07/2018 08:06:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/07/2018 10:58:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/07/2018 06:30:48	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/07/2018 13:04:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
25/07/2018 02:41:05	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
25/07/2018 17:59:58	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/07/2018 05:23:33	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/07/2018 06:26:05	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/07/2018 08:57:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/07/2018 16:45:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/07/2018 18:01:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/07/2018 19:15:57	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/07/2018 00:30:07	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
27/07/2018 07:12:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/07/2018 07:46:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/07/2018 08:02:51	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/07/2018 16:09:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/07/2018 18:13:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/07/2018 21:55:53	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/07/2018 07:56:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/07/2018 16:40:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/07/2018 18:21:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2018 09:32:00	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
29/07/2018 14:11:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2018 15:37:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/07/2018 23:28:13	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
30/07/2018 01:49:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/07/2018 18:24:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/07/2018 03:43:21	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/07/2018 09:18:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/08/2018 00:33:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/08/2018 07:27:39	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/08/2018 09:10:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
01/08/2018 11:25:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/08/2018 13:20:50	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/08/2018 15:12:53	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/08/2018 20:16:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/08/2018 10:29:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/08/2018 08:36:50	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/08/2018 16:38:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/08/2018 06:07:46	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/08/2018 15:43:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/08/2018 20:22:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/08/2018 20:29:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
05/08/2018 21:08:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/08/2018 08:16:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/08/2018 15:58:53	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
06/08/2018 17:38:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/08/2018 09:50:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
07/08/2018 21:40:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/08/2018 22:03:51	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/08/2018 04:11:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/08/2018 18:51:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/08/2018 22:10:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/08/2018 01:14:51	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
09/08/2018 17:08:01	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
09/08/2018 18:48:08	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
09/08/2018 22:28:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/08/2018 06:07:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/08/2018 08:21:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/08/2018 11:04:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/08/2018 16:27:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/08/2018 05:12:30	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/08/2018 10:58:12	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
11/08/2018 16:50:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/08/2018 19:00:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/08/2018 06:32:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/08/2018 11:40:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/08/2018 14:16:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
12/08/2018 16:27:45	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
12/08/2018 17:38:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2018 22:44:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/08/2018 10:59:07	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/08/2018 17:08:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/08/2018 09:23:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/08/2018 11:08:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/08/2018 12:47:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
15/08/2018 05:26:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
15/08/2018 07:32:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/08/2018 12:17:00	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
15/08/2018 15:06:33	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
16/08/2018 00:17:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/08/2018 06:12:11	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/08/2018 08:37:29	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
16/08/2018 10:19:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
16/08/2018 14:30:27	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/08/2018 19:16:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/08/2018 21:51:57	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
17/08/2018 06:50:32	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
17/08/2018 21:34:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/08/2018 01:31:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/08/2018 02:00:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/08/2018 04:35:39	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/08/2018 16:32:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/08/2018 16:55:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/08/2018 21:07:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2018 05:04:24	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/08/2018 16:48:56	Fire	Smoke/condensation	Air conditioning	Hospital (P)
20/08/2018 01:14:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/08/2018 03:10:27	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/08/2018 03:21:04	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/08/2018 08:45:45	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
20/08/2018 12:46:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/08/2018 16:32:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/08/2018 19:33:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/08/2018 09:09:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/08/2018 15:36:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/08/2018 16:21:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/08/2018 17:06:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
21/08/2018 19:14:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/08/2018 19:52:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/08/2018 20:30:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/08/2018 21:43:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/08/2018 06:07:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/08/2018 07:21:35	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/08/2018 10:08:52	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
22/08/2018 10:43:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/08/2018 16:12:31	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/08/2018 01:14:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/08/2018 15:58:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/08/2018 23:19:07	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/08/2018 10:51:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/08/2018 12:49:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/08/2018 15:57:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/08/2018 16:12:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/08/2018 17:35:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/08/2018 07:17:45	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/08/2018 06:53:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/08/2018 14:18:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/08/2018 04:08:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/08/2018 11:30:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/08/2018 17:19:39	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
29/08/2018 19:37:51	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
29/08/2018 22:46:18	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
30/08/2018 04:11:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/08/2018 07:03:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/08/2018 08:09:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/08/2018 05:06:40	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
31/08/2018 05:36:33	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
31/08/2018 08:23:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/08/2018 11:24:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/08/2018 21:21:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/09/2018 08:29:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/09/2018 09:01:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/09/2018 10:19:44	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
01/09/2018 18:15:35	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
02/09/2018 14:09:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/09/2018 03:01:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
03/09/2018 08:24:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/09/2018 14:10:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/09/2018 10:31:10	Fire alarm due to Apparatus	System: heat	Poor maintenance of system	Hospital (P)
04/09/2018 15:51:42	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
05/09/2018 13:18:04	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/09/2018 14:29:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/09/2018 18:14:45	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/09/2018 19:06:04	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/09/2018 01:21:20	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/09/2018 02:55:23	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/09/2018 08:51:16	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/09/2018 10:21:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/09/2018 13:34:22	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
06/09/2018 18:49:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/09/2018 00:03:54	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/09/2018 05:39:44	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/09/2018 06:38:49	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/09/2018 08:46:58	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/09/2018 19:20:26	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
08/09/2018 00:12:26	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/09/2018 06:35:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/09/2018 18:34:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/09/2018 19:02:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/09/2018 20:39:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/09/2018 21:30:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/09/2018 21:38:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/09/2018 05:46:13	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/09/2018 10:39:48	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
10/09/2018 06:39:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2018 09:42:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2018 10:05:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2018 13:04:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2018 15:03:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/09/2018 16:56:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2018 16:58:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2018 17:58:26	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/09/2018 23:37:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
11/09/2018 07:34:17	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/09/2018 08:08:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/09/2018 13:13:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/09/2018 14:05:40	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
12/09/2018 21:00:37	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/09/2018 00:19:03	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
13/09/2018 12:41:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/09/2018 08:27:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/09/2018 11:06:53	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
15/09/2018 11:16:54	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
15/09/2018 12:12:14	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/09/2018 13:50:33	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/09/2018 06:15:32	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/09/2018 21:44:12	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
17/09/2018 02:34:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/09/2018 03:00:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/09/2018 04:04:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/09/2018 04:25:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/09/2018 04:47:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/09/2018 09:33:04	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
17/09/2018 10:32:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/09/2018 20:42:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/09/2018 08:04:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/09/2018 11:18:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/09/2018 12:38:17	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/09/2018 19:40:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/09/2018 01:16:38	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/09/2018 10:41:19	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
19/09/2018 12:05:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/09/2018 15:13:31	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
19/09/2018 18:48:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/09/2018 19:23:12	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
20/09/2018 02:12:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/09/2018 19:05:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/09/2018 19:42:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/09/2018 01:24:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/09/2018 13:46:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
21/09/2018 15:20:30	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/09/2018 17:28:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/09/2018 17:32:15	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
21/09/2018 20:22:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/09/2018 07:18:27	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/09/2018 11:40:29	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/09/2018 12:56:12	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/09/2018 02:43:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/09/2018 08:38:25	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/09/2018 10:19:53	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/09/2018 14:11:26	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/09/2018 17:30:13	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/09/2018 22:21:25	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/09/2018 06:11:34	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
24/09/2018 12:04:20	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/09/2018 12:41:02	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/09/2018 23:03:51	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
25/09/2018 10:45:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/09/2018 20:29:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/09/2018 07:51:53	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/09/2018 08:45:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/09/2018 09:46:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/09/2018 10:08:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/09/2018 20:28:15	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/09/2018 23:44:06	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
27/09/2018 08:07:56	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/09/2018 13:12:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/09/2018 15:11:24	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/09/2018 10:06:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/09/2018 13:22:52	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/09/2018 03:42:45	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/09/2018 10:56:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/09/2018 18:53:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/09/2018 20:29:32	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
29/09/2018 22:50:15	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/09/2018 08:23:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/09/2018 11:02:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/09/2018 19:36:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/09/2018 20:57:23	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
01/10/2018 08:53:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/10/2018 15:17:14	Fire alarm due to Apparatus	System: sprinkler	Alarm actuated - Other reason	Hospital (P)
01/10/2018 19:26:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/10/2018 19:47:47	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
02/10/2018 11:37:34	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/10/2018 09:26:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/10/2018 11:58:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/10/2018 11:59:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/10/2018 14:39:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/10/2018 20:21:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/10/2018 03:38:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/10/2018 08:21:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/10/2018 11:47:15	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
04/10/2018 14:16:18	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/10/2018 17:41:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/10/2018 20:31:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/10/2018 08:18:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/10/2018 20:28:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/10/2018 10:37:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/10/2018 10:40:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/10/2018 17:25:43	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/10/2018 07:39:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/10/2018 15:22:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
07/10/2018 18:50:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/10/2018 20:31:46	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
07/10/2018 23:11:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/10/2018 23:02:47	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
09/10/2018 11:04:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/10/2018 13:35:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/10/2018 14:07:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/10/2018 21:00:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
10/10/2018 01:05:48	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/10/2018 07:56:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/10/2018 07:58:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/10/2018 20:26:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/10/2018 03:53:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/10/2018 12:13:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/10/2018 18:41:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/10/2018 14:16:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/10/2018 17:25:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/10/2018 21:01:15	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
15/10/2018 03:25:46	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
15/10/2018 17:39:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/10/2018 21:24:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/10/2018 12:38:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/10/2018 12:41:51	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/10/2018 16:02:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/10/2018 21:12:40	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
16/10/2018 22:10:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/10/2018 22:14:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/10/2018 23:06:16	Fire	Smoke/condensation	Steam	Hospital (P)
17/10/2018 08:25:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/10/2018 15:22:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/10/2018 22:41:52	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
18/10/2018 15:14:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/10/2018 16:58:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/10/2018 17:01:48	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/10/2018 04:51:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/10/2018 05:38:21	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/10/2018 08:21:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/10/2018 10:08:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/10/2018 11:48:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/10/2018 06:52:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/10/2018 22:06:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/10/2018 10:07:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/10/2018 13:12:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/10/2018 20:09:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/10/2018 20:13:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/10/2018 20:59:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/10/2018 22:55:34	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/10/2018 07:24:09	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
22/10/2018 08:22:07	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
22/10/2018 16:06:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/10/2018 23:45:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/10/2018 07:58:32	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/10/2018 09:43:21	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
23/10/2018 16:11:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/10/2018 10:16:48	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
24/10/2018 12:12:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/10/2018 15:44:12	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/10/2018 19:04:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/10/2018 14:03:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/10/2018 16:30:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/10/2018 16:46:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/10/2018 10:38:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/10/2018 14:06:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/10/2018 20:57:58	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
26/10/2018 22:18:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/10/2018 02:56:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/10/2018 07:43:37	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/10/2018 17:44:29	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
28/10/2018 00:04:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/10/2018 07:10:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/10/2018 13:33:21	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
29/10/2018 15:32:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/10/2018 20:41:17	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
30/10/2018 10:31:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/10/2018 13:10:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/10/2018 16:16:05	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/10/2018 18:52:45	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/10/2018 01:23:29	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
31/10/2018 10:41:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/10/2018 18:26:51	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
31/10/2018 19:51:10	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
31/10/2018 23:38:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/11/2018 05:22:46	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
01/11/2018 06:52:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
01/11/2018 16:01:05	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/11/2018 17:05:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/11/2018 18:40:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/11/2018 09:56:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/11/2018 16:26:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/11/2018 16:55:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/11/2018 13:41:54	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
03/11/2018 22:29:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/11/2018 03:35:21	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
04/11/2018 07:52:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/11/2018 10:02:33	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
04/11/2018 10:43:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/11/2018 13:29:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/11/2018 14:00:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/11/2018 21:47:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/11/2018 08:02:32	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
05/11/2018 09:14:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/11/2018 23:21:07	Fire	Smell of burning	Overheating appliance	Hospital (P)
06/11/2018 10:00:29	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
06/11/2018 11:49:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/11/2018 15:39:27	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/11/2018 17:24:30	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/11/2018 20:49:55	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
07/11/2018 00:45:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/11/2018 08:33:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/11/2018 08:55:44	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
07/11/2018 13:40:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
07/11/2018 17:26:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/11/2018 21:46:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/11/2018 07:08:10	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
08/11/2018 07:42:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/11/2018 12:20:54	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/11/2018 16:09:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/11/2018 17:27:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/11/2018 23:11:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
10/11/2018 18:51:24	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
11/11/2018 06:31:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/11/2018 16:17:30	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/11/2018 17:12:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/11/2018 08:27:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/11/2018 08:31:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/11/2018 08:47:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/11/2018 14:04:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/11/2018 14:57:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
12/11/2018 15:56:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
12/11/2018 16:42:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/11/2018 19:35:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/11/2018 02:42:42	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
13/11/2018 10:07:40	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/11/2018 03:20:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/11/2018 09:41:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
14/11/2018 10:40:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/11/2018 23:24:29	Fire	Burnt toast/food	Barbeque not out of control	Hospital (P)
19/11/2018 06:40:25	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
19/11/2018 15:10:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/11/2018 21:51:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/11/2018 05:44:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/11/2018 16:50:48	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/11/2018 21:06:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/11/2018 03:38:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/11/2018 05:09:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/11/2018 10:37:33	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
22/11/2018 07:19:52	Fire alarm due to Apparatus	External Factors	Power surge	Hospital (P)
22/11/2018 09:04:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/11/2018 15:51:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/11/2018 18:44:20	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
22/11/2018 19:00:08	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
22/11/2018 22:08:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/11/2018 08:52:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/11/2018 09:46:40	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/11/2018 10:10:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/11/2018 16:13:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/11/2018 08:50:33	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/11/2018 09:53:01	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/11/2018 10:24:44	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/11/2018 09:19:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/11/2018 12:11:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/11/2018 12:57:14	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/11/2018 08:22:50	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
27/11/2018 12:12:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/11/2018 15:25:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/11/2018 19:04:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/11/2018 00:32:49	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/11/2018 07:06:43	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/11/2018 13:53:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
28/11/2018 20:03:40	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
28/11/2018 20:38:24	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/11/2018 23:03:57	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/11/2018 23:54:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/11/2018 05:16:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/11/2018 07:15:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/11/2018 08:45:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/11/2018 01:25:12	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/11/2018 06:20:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/11/2018 14:20:08	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
01/12/2018 13:28:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/12/2018 14:11:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/12/2018 15:07:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/12/2018 01:58:27	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
02/12/2018 06:58:06	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
02/12/2018 08:23:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/12/2018 10:16:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/12/2018 13:59:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/12/2018 01:47:04	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
03/12/2018 09:44:49	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
03/12/2018 15:32:18	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
04/12/2018 06:58:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/12/2018 10:04:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/12/2018 14:05:13	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/12/2018 14:42:08	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/12/2018 16:34:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/12/2018 18:21:11	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
05/12/2018 00:36:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/12/2018 02:15:01	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/12/2018 03:47:36	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
05/12/2018 05:30:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/12/2018 06:47:29	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/12/2018 13:58:59	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
05/12/2018 15:09:38	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
05/12/2018 20:22:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/12/2018 18:14:08	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
07/12/2018 10:34:37	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
07/12/2018 13:15:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/12/2018 14:14:50	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/12/2018 16:58:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/12/2018 18:12:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/12/2018 19:42:13	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
08/12/2018 14:12:01	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
08/12/2018 22:38:07	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/12/2018 07:10:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/12/2018 14:18:27	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
10/12/2018 15:36:21	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/12/2018 16:59:57	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/12/2018 23:50:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/12/2018 11:07:16	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/12/2018 15:08:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/12/2018 16:42:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/12/2018 22:24:04	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/12/2018 23:45:35	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
13/12/2018 00:23:42	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
13/12/2018 02:12:03	Fire	Smoke/condensation	Steam	Hospital (P)
13/12/2018 08:57:26	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/12/2018 09:23:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/12/2018 11:23:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/12/2018 20:52:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/12/2018 21:00:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/12/2018 22:18:37	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/12/2018 08:10:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
15/12/2018 16:15:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/12/2018 16:39:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/12/2018 19:37:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/12/2018 22:08:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
15/12/2018 22:13:08	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
16/12/2018 00:49:40	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
16/12/2018 18:05:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/12/2018 20:14:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/12/2018 21:08:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
17/12/2018 21:48:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/12/2018 12:48:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/12/2018 13:53:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/12/2018 16:14:04	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
18/12/2018 20:20:05	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
19/12/2018 00:39:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/12/2018 02:20:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/12/2018 03:32:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/12/2018 14:10:28	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/12/2018 16:33:15	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/12/2018 17:39:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/12/2018 21:59:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2018 17:49:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2018 20:14:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2018 23:03:18	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/12/2018 23:09:21	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
24/12/2018 07:14:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/12/2018 16:04:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/12/2018 18:42:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/12/2018 01:43:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/12/2018 07:50:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/12/2018 13:54:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/12/2018 07:56:23	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/12/2018 23:57:15	Fire alarm due to Apparatus	Contaminants	Thrips/Small insects	Hospital (P)
27/12/2018 09:08:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/12/2018 09:55:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/12/2018 12:21:32	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/12/2018 14:13:27	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/12/2018 17:31:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/12/2018 21:18:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/12/2018 01:08:10	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
29/12/2018 02:57:27	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/12/2018 19:27:45	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
29/12/2018 21:02:51	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
29/12/2018 22:11:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/12/2018 07:32:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/12/2018 15:25:04	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/12/2018 15:33:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/12/2018 15:40:44	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
31/12/2018 11:06:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
01/01/2019 21:19:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/01/2019 09:36:21	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/01/2019 10:40:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/01/2019 11:25:35	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
02/01/2019 20:41:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/01/2019 12:07:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/01/2019 18:15:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
05/01/2019 01:48:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/01/2019 08:29:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/01/2019 21:47:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/01/2019 09:29:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/01/2019 13:39:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/01/2019 02:35:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/01/2019 08:39:29	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/01/2019 09:12:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/01/2019 10:51:29	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/01/2019 13:01:27	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
09/01/2019 13:49:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/01/2019 04:21:14	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
10/01/2019 07:08:49	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
10/01/2019 10:12:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/01/2019 14:51:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
10/01/2019 22:26:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/01/2019 07:50:25	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/01/2019 13:46:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
12/01/2019 06:46:12	Fire	Smell of burning	Overheating appliance	Hospital (P)
12/01/2019 16:03:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/01/2019 18:38:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/01/2019 09:08:06	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/01/2019 12:06:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/01/2019 13:08:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2019 12:24:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2019 19:33:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2019 19:47:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/01/2019 08:40:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/01/2019 09:41:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/01/2019 15:34:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/01/2019 04:44:38	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
16/01/2019 12:54:35	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
17/01/2019 00:32:49	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
17/01/2019 06:39:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/01/2019 20:39:12	Fire alarm due to Apparatus	External Factors	Power surge	Hospital (P)
18/01/2019 02:11:37	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
18/01/2019 03:00:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/01/2019 07:51:08	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
18/01/2019 09:12:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/01/2019 09:46:19	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/01/2019 14:42:39	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
18/01/2019 21:16:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/01/2019 21:46:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/01/2019 02:38:13	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
19/01/2019 13:16:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/01/2019 13:54:08	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
20/01/2019 03:51:08	Fire	Smoke/condensation	Steam	Hospital (P)
21/01/2019 09:06:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/01/2019 08:02:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/01/2019 14:07:47	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/01/2019 17:21:44	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/01/2019 20:12:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/01/2019 22:38:45	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/01/2019 14:03:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/01/2019 19:11:33	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/01/2019 19:46:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/01/2019 10:23:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/01/2019 15:10:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/01/2019 17:55:25	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/01/2019 04:32:15	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
25/01/2019 08:10:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/01/2019 08:44:56	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/01/2019 13:25:38	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
25/01/2019 17:00:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/01/2019 17:00:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/01/2019 09:15:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/01/2019 09:37:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/01/2019 20:22:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/01/2019 23:21:28	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
27/01/2019 03:33:02	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/01/2019 09:48:13	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/01/2019 09:21:24	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/01/2019 13:02:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/01/2019 13:26:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/01/2019 18:16:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
28/01/2019 18:30:25	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
28/01/2019 19:11:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/01/2019 00:16:38	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/01/2019 00:17:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/01/2019 06:59:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/01/2019 10:09:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/01/2019 11:43:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/01/2019 13:10:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/01/2019 13:50:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/01/2019 14:07:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/01/2019 14:31:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/01/2019 22:32:21	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/01/2019 08:17:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/01/2019 12:24:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/01/2019 19:46:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
31/01/2019 07:18:40	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
01/02/2019 14:39:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/02/2019 16:06:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
01/02/2019 23:35:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/02/2019 11:49:07	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/02/2019 09:04:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/02/2019 10:51:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/02/2019 13:42:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/02/2019 10:06:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/02/2019 20:59:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/02/2019 22:08:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
05/02/2019 09:23:40	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
05/02/2019 09:31:46	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/02/2019 10:44:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/02/2019 15:54:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/02/2019 18:46:46	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
05/02/2019 20:33:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/02/2019 00:41:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/02/2019 12:00:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/02/2019 13:14:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/02/2019 21:07:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/02/2019 04:03:50	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
07/02/2019 15:21:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/02/2019 19:14:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/02/2019 06:46:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/02/2019 13:35:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/02/2019 15:49:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/02/2019 00:35:23	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
10/02/2019 04:06:55	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/02/2019 13:05:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/02/2019 19:19:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
10/02/2019 19:29:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/02/2019 02:41:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/02/2019 11:47:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/02/2019 20:53:53	Fire alarm due to Apparatus	System: Animal	Fire alarm actuated accidentally by animal	Hospital (P)
12/02/2019 13:53:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/02/2019 15:28:18	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/02/2019 16:08:25	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/02/2019 22:29:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/02/2019 11:02:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/02/2019 06:45:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/02/2019 13:57:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/02/2019 07:50:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/02/2019 10:38:01	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/02/2019 19:46:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/02/2019 02:01:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/02/2019 05:05:45	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/02/2019 18:18:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/02/2019 01:01:00	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
18/02/2019 18:21:06	Good Intent false alarm	Good Intent false alarm	Call to special service - No incident at reported location	Hospital (P)
19/02/2019 07:18:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
20/02/2019 12:07:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
20/02/2019 15:02:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/02/2019 18:56:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/02/2019 04:07:56	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
21/02/2019 07:53:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/02/2019 13:35:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/02/2019 19:07:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/02/2019 19:14:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/02/2019 22:17:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/02/2019 13:53:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/02/2019 14:11:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/02/2019 14:48:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/02/2019 16:03:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/02/2019 07:56:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/02/2019 09:40:57	Fire	Smell of burning	Overheating appliance	Hospital (P)
23/02/2019 11:02:44	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/02/2019 11:35:13	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/02/2019 18:59:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/02/2019 21:43:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/02/2019 16:13:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/02/2019 02:21:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/02/2019 04:16:28	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/02/2019 10:51:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/02/2019 13:16:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/02/2019 16:44:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/02/2019 17:15:13	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/02/2019 10:22:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2019 19:37:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/02/2019 01:18:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/02/2019 08:41:36	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
27/02/2019 13:32:22	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
27/02/2019 16:20:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/02/2019 20:02:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/02/2019 05:04:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/02/2019 08:16:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/02/2019 15:15:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/02/2019 15:56:30	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/03/2019 04:56:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/03/2019 08:22:48	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/03/2019 21:20:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/03/2019 05:10:30	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
02/03/2019 10:05:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/03/2019 15:18:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/03/2019 19:07:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/03/2019 06:24:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/03/2019 18:29:40	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
04/03/2019 22:20:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/03/2019 02:55:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/03/2019 14:10:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/03/2019 15:15:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/03/2019 23:36:35	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/03/2019 11:24:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/03/2019 21:58:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/03/2019 04:17:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/03/2019 12:29:06	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
07/03/2019 12:46:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/03/2019 22:14:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/03/2019 04:25:04	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/03/2019 09:16:09	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
08/03/2019 11:55:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/03/2019 14:25:41	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
08/03/2019 22:57:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/03/2019 23:39:27	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
09/03/2019 03:28:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/03/2019 08:38:19	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
09/03/2019 10:28:33	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
09/03/2019 15:46:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/03/2019 17:09:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/03/2019 19:36:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/03/2019 19:40:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/03/2019 20:14:56	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
09/03/2019 21:28:57	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/03/2019 09:37:14	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/03/2019 19:56:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/03/2019 23:06:58	Fire alarm due to Apparatus	System: other	Incorrect positioning	Hospital (P)
11/03/2019 00:36:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/03/2019 01:57:41	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/03/2019 10:43:38	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
11/03/2019 12:02:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/03/2019 12:53:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
12/03/2019 11:03:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/03/2019 11:41:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/03/2019 21:07:20	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/03/2019 05:30:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/03/2019 11:41:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/03/2019 12:05:36	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/03/2019 14:36:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/03/2019 15:55:15	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/03/2019 11:48:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/03/2019 14:02:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/03/2019 14:54:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/03/2019 20:03:23	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/03/2019 20:39:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/03/2019 22:00:29	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
15/03/2019 10:34:16	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/03/2019 15:21:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/03/2019 23:37:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
16/03/2019 02:55:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/03/2019 08:13:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/03/2019 09:28:01	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/03/2019 21:59:20	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/03/2019 19:01:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/03/2019 08:48:32	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/03/2019 10:03:20	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/03/2019 13:28:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/03/2019 07:32:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/03/2019 15:31:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/03/2019 16:53:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/03/2019 17:51:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/03/2019 18:44:00	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
22/03/2019 07:58:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/03/2019 16:44:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/03/2019 01:05:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/03/2019 07:52:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/03/2019 12:20:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/03/2019 14:16:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/03/2019 16:39:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/03/2019 17:56:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/03/2019 09:15:51	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/03/2019 11:30:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/03/2019 14:00:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/03/2019 21:44:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/03/2019 06:23:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/03/2019 09:00:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
26/03/2019 10:33:02	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
26/03/2019 13:38:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/03/2019 19:05:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/03/2019 21:27:49	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
27/03/2019 13:50:44	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/03/2019 15:41:03	Malicious False Alarm	Malicious False Alarm	Malicious call to an incident - other	Hospital (P)
28/03/2019 00:59:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/03/2019 08:12:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/03/2019 08:58:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/03/2019 11:26:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
28/03/2019 15:58:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
28/03/2019 18:58:01	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
29/03/2019 00:07:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/03/2019 00:20:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/03/2019 16:40:17	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
30/03/2019 01:23:54	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/03/2019 10:17:55	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
30/03/2019 22:07:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
31/03/2019 17:03:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
31/03/2019 19:55:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/04/2019 13:07:01	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
01/04/2019 14:45:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/04/2019 18:39:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/04/2019 10:14:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/04/2019 10:40:55	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
02/04/2019 14:43:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/04/2019 20:49:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/04/2019 07:09:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/04/2019 16:18:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/04/2019 19:19:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/04/2019 20:41:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/04/2019 13:39:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
04/04/2019 15:31:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
05/04/2019 17:05:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/04/2019 19:02:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/04/2019 01:24:33	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
06/04/2019 03:30:33	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/04/2019 15:06:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/04/2019 15:37:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/04/2019 21:04:50	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/04/2019 22:57:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2019 00:42:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2019 10:44:35	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/04/2019 14:26:48	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
07/04/2019 18:00:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/04/2019 19:05:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/04/2019 08:18:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/04/2019 10:51:00	Fire alarm due to Apparatus	System: other	Incorrect positioning	Hospital (P)
08/04/2019 12:09:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/04/2019 23:43:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/04/2019 07:24:29	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
09/04/2019 20:18:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/04/2019 20:50:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/04/2019 21:10:09	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
10/04/2019 07:33:19	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/04/2019 11:22:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/04/2019 14:22:43	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
10/04/2019 17:34:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/04/2019 21:51:39	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
11/04/2019 20:47:58	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/04/2019 07:46:18	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/04/2019 07:59:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/04/2019 08:07:48	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/04/2019 11:00:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/04/2019 12:23:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
12/04/2019 15:06:39	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/04/2019 17:27:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/04/2019 18:24:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/04/2019 19:25:57	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/04/2019 01:35:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/04/2019 13:12:15	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/04/2019 14:27:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/04/2019 23:09:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/04/2019 00:22:40	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
14/04/2019 00:36:45	Fire	Smoke/condensation	Air conditioning	Hospital (P)
14/04/2019 09:17:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/04/2019 08:14:38	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/04/2019 09:38:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/04/2019 12:52:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/04/2019 18:30:30	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
17/04/2019 01:04:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/04/2019 01:31:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/04/2019 06:08:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/04/2019 06:34:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/04/2019 07:40:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/04/2019 09:06:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/04/2019 11:05:42	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
17/04/2019 11:12:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/04/2019 16:45:53	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
18/04/2019 18:28:12	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/04/2019 20:36:01	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
19/04/2019 00:43:09	Good Intent false alarm	Good Intent false alarm	Special Service - Brigade action not required	Hospital (P)
19/04/2019 16:58:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/04/2019 23:33:29	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
20/04/2019 08:33:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/04/2019 11:41:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2019 05:45:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2019 06:33:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2019 07:12:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2019 14:35:50	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
22/04/2019 10:44:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/04/2019 08:21:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/04/2019 18:37:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/04/2019 08:26:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/04/2019 10:03:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/04/2019 10:24:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/04/2019 12:30:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/04/2019 13:58:24	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
24/04/2019 18:51:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2019 06:53:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2019 12:27:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/04/2019 01:56:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/04/2019 13:31:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/04/2019 13:44:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/04/2019 15:50:23	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
26/04/2019 17:24:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/04/2019 23:10:12	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/04/2019 13:24:16	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
27/04/2019 23:43:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/04/2019 09:13:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/04/2019 10:20:28	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/04/2019 11:47:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
28/04/2019 14:50:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/04/2019 15:51:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/04/2019 07:29:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/04/2019 12:01:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/04/2019 12:38:23	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
29/04/2019 14:05:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/04/2019 16:41:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/04/2019 17:34:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/04/2019 18:59:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/04/2019 20:06:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/04/2019 08:28:46	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
30/04/2019 09:29:58	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
30/04/2019 12:18:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
01/05/2019 00:49:39	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
01/05/2019 06:32:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/05/2019 00:36:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/05/2019 06:09:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/05/2019 07:14:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/05/2019 12:19:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/05/2019 21:18:26	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
03/05/2019 00:05:07	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/05/2019 10:25:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/05/2019 15:18:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/05/2019 06:04:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/05/2019 10:39:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/05/2019 13:43:28	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
04/05/2019 17:38:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/05/2019 23:49:33	Fire	Smell of burning	Overheating appliance	Hospital (P)
05/05/2019 23:29:20	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
06/05/2019 12:39:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/05/2019 17:13:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/05/2019 19:02:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/05/2019 06:54:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/05/2019 10:07:17	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/05/2019 14:02:33	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
09/05/2019 14:06:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/05/2019 14:37:05	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
10/05/2019 06:45:11	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/05/2019 12:19:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/05/2019 23:04:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/05/2019 12:59:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/05/2019 14:13:33	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
11/05/2019 14:46:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/05/2019 16:41:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/05/2019 18:33:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/05/2019 19:21:24	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/05/2019 21:46:52	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
12/05/2019 00:44:29	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/05/2019 08:40:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2019 12:02:02	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/05/2019 14:16:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/05/2019 14:40:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/05/2019 17:13:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2019 21:10:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2019 22:42:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/05/2019 23:32:04	Fire	Smoke/condensation	Steam	Hospital (P)
13/05/2019 07:04:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/05/2019 08:04:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
14/05/2019 03:38:37	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
14/05/2019 12:13:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/05/2019 19:04:41	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/05/2019 22:50:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
15/05/2019 16:38:10	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/05/2019 02:46:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/05/2019 11:21:13	Fire	Smoke/condensation	Air conditioning	Hospital (P)
16/05/2019 11:29:01	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/05/2019 12:25:25	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/05/2019 13:02:30	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/05/2019 14:05:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/05/2019 17:26:57	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
16/05/2019 19:01:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/05/2019 21:51:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/05/2019 02:07:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/05/2019 08:41:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/05/2019 20:10:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/05/2019 20:25:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/05/2019 23:53:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/05/2019 05:32:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/05/2019 07:10:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/05/2019 09:24:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/05/2019 23:56:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/05/2019 09:38:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/05/2019 10:49:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/05/2019 10:37:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/05/2019 17:05:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/05/2019 17:41:56	Fire	Smoke/condensation	Steam	Hospital (P)
20/05/2019 18:03:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/05/2019 20:51:06	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
21/05/2019 06:38:37	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
21/05/2019 10:58:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/05/2019 17:17:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/05/2019 18:13:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/05/2019 21:54:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/05/2019 03:20:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/05/2019 12:57:03	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/05/2019 14:25:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/05/2019 16:07:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/05/2019 22:28:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/05/2019 04:50:38	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/05/2019 18:34:50	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/05/2019 21:50:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/05/2019 05:08:55	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/05/2019 08:06:32	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/05/2019 17:36:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/05/2019 23:18:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/05/2019 20:49:42	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/05/2019 18:41:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/05/2019 23:18:30	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/05/2019 01:08:23	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
27/05/2019 01:53:29	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
27/05/2019 05:13:29	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
27/05/2019 07:10:21	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/05/2019 16:08:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/05/2019 16:41:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/05/2019 20:57:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/05/2019 11:38:07	Fire	Smell of burning	Overheating appliance	Hospital (P)
28/05/2019 14:59:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/05/2019 09:40:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/05/2019 19:46:56	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
30/05/2019 19:37:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
31/05/2019 07:53:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/05/2019 19:02:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/05/2019 20:20:38	Fire alarm due to Apparatus	System: other	Incorrect positioning	Hospital (P)
01/06/2019 16:02:02	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/06/2019 13:20:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/06/2019 15:46:56	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/06/2019 00:32:35	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
03/06/2019 12:36:39	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
03/06/2019 14:39:49	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
03/06/2019 18:18:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/06/2019 19:45:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/06/2019 22:40:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/06/2019 06:57:31	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/06/2019 12:37:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/06/2019 19:37:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/06/2019 20:41:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/06/2019 21:40:56	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/06/2019 00:02:41	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
05/06/2019 03:10:56	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/06/2019 03:49:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/06/2019 04:15:19	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
05/06/2019 14:32:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/06/2019 14:39:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/06/2019 18:43:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/06/2019 10:03:18	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/06/2019 23:57:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/06/2019 07:35:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/06/2019 14:16:51	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/06/2019 07:44:32	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/06/2019 08:34:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/06/2019 08:35:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/06/2019 16:40:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/06/2019 23:38:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/06/2019 01:40:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/06/2019 02:16:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/06/2019 09:55:56	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
09/06/2019 15:47:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/06/2019 19:32:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/06/2019 01:38:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
10/06/2019 03:57:29	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
11/06/2019 02:09:31	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
11/06/2019 02:18:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/06/2019 04:03:54	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
11/06/2019 04:33:22	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
11/06/2019 08:37:17	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/06/2019 19:13:32	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
12/06/2019 00:54:32	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
12/06/2019 01:33:23	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/06/2019 06:06:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/06/2019 07:27:25	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/06/2019 11:48:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/06/2019 15:17:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/06/2019 21:27:14	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
13/06/2019 22:23:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
14/06/2019 04:37:10	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/06/2019 11:12:32	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
14/06/2019 12:37:53	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/06/2019 15:30:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/06/2019 16:13:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/06/2019 20:03:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/06/2019 09:29:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/06/2019 23:53:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/06/2019 02:14:12	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/06/2019 07:09:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/06/2019 10:55:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/06/2019 13:04:45	Fire	Smoke/condensation	Steam	Hospital (P)
17/06/2019 22:59:41	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/06/2019 16:02:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/06/2019 18:29:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/06/2019 21:28:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/06/2019 11:04:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/06/2019 17:38:32	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/06/2019 22:42:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/06/2019 11:59:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/06/2019 13:14:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/06/2019 13:38:08	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
20/06/2019 17:59:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/06/2019 02:59:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/06/2019 10:56:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/06/2019 19:31:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/06/2019 02:43:36	Fire alarm due to Apparatus	Contaminants	Thrips/Small insects	Hospital (P)
24/06/2019 03:29:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/06/2019 08:48:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/06/2019 13:06:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/06/2019 16:23:37	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
24/06/2019 19:14:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/06/2019 08:42:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/06/2019 08:59:31	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
25/06/2019 16:45:25	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
25/06/2019 17:15:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/06/2019 20:32:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/06/2019 21:35:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/06/2019 23:43:35	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/06/2019 01:46:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
26/06/2019 06:49:04	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
26/06/2019 11:59:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/06/2019 13:40:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/06/2019 17:41:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/06/2019 18:30:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/06/2019 08:27:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/06/2019 10:06:24	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
27/06/2019 21:28:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/06/2019 09:40:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/06/2019 23:30:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/06/2019 12:48:03	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
29/06/2019 15:39:48	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/06/2019 18:18:00	Fire alarm due to Apparatus	System: heat	Alarm actuated - Other reason	Hospital (P)
29/06/2019 19:25:05	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
30/06/2019 02:41:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/06/2019 07:28:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/06/2019 18:40:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/07/2019 21:00:38	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
01/07/2019 21:46:38	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
01/07/2019 23:09:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/07/2019 00:40:57	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
02/07/2019 07:37:36	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/07/2019 09:23:05	Fire alarm due to Apparatus	System: flame	Poor maintenance of system	Hospital (P)
02/07/2019 18:13:09	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
02/07/2019 19:20:23	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
03/07/2019 11:51:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/07/2019 17:45:38	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
03/07/2019 18:45:34	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/07/2019 19:45:30	Good Intent false alarm	Good Intent false alarm	Special Service - Brigade action not required	Hospital (P)
03/07/2019 23:48:13	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
04/07/2019 03:44:52	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
04/07/2019 07:18:39	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
04/07/2019 10:38:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/07/2019 13:23:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/07/2019 15:16:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/07/2019 15:34:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/07/2019 13:52:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/07/2019 19:09:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/07/2019 11:43:59	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/07/2019 15:36:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/07/2019 13:14:15	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
09/07/2019 08:50:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/07/2019 15:20:08	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
10/07/2019 05:35:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/07/2019 10:55:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/07/2019 10:58:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/07/2019 12:25:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/07/2019 17:29:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/07/2019 22:59:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/07/2019 01:58:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/07/2019 08:34:05	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
11/07/2019 09:52:11	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/07/2019 11:19:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/07/2019 14:42:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/07/2019 23:29:15	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/07/2019 18:37:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/07/2019 08:30:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/07/2019 11:17:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/07/2019 11:41:58	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
13/07/2019 12:42:00	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
13/07/2019 16:12:24	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/07/2019 22:35:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/07/2019 04:47:19	Fire	Smell of burning	Overheating appliance	Hospital (P)
14/07/2019 18:48:47	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/07/2019 09:57:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/07/2019 10:41:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/07/2019 12:33:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/07/2019 04:42:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/07/2019 07:24:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/07/2019 15:40:25	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
17/07/2019 21:26:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/07/2019 21:53:15	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/07/2019 23:25:41	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/07/2019 01:19:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/07/2019 02:43:28	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
18/07/2019 08:50:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
18/07/2019 10:38:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/07/2019 21:01:50	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/07/2019 21:39:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
18/07/2019 22:19:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/07/2019 22:29:00	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
19/07/2019 14:23:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/07/2019 14:45:06	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
19/07/2019 20:09:27	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/07/2019 06:34:05	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
20/07/2019 08:08:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/07/2019 08:27:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/07/2019 08:37:48	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/07/2019 09:39:11	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
20/07/2019 12:40:04	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
20/07/2019 20:32:32	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
21/07/2019 07:53:59	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
22/07/2019 04:42:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/07/2019 08:13:18	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/07/2019 02:45:08	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
23/07/2019 13:58:28	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/07/2019 14:43:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/07/2019 08:48:45	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
24/07/2019 09:52:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/07/2019 11:54:46	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/07/2019 15:25:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/07/2019 23:07:37	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
25/07/2019 05:21:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/07/2019 07:39:44	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/07/2019 10:07:57	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/07/2019 11:28:05	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/07/2019 11:41:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/07/2019 13:30:36	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
25/07/2019 18:18:28	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
25/07/2019 18:35:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/07/2019 20:55:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/07/2019 21:09:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/07/2019 01:21:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/07/2019 07:46:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/07/2019 16:04:27	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
26/07/2019 17:41:45	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
26/07/2019 20:01:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/07/2019 20:12:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/07/2019 07:34:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/07/2019 10:08:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/07/2019 10:47:05	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/07/2019 06:21:21	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/07/2019 11:55:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2019 06:55:25	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
29/07/2019 10:15:43	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
29/07/2019 20:47:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
30/07/2019 14:31:53	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
30/07/2019 20:43:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/07/2019 11:25:29	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
31/07/2019 14:23:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/08/2019 07:16:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/08/2019 08:55:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
03/08/2019 01:37:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/08/2019 08:29:14	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/08/2019 22:28:46	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
03/08/2019 22:50:44	Fire	Smoke/condensation	Steam	Hospital (P)
04/08/2019 16:29:05	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
04/08/2019 18:26:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/08/2019 22:31:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/08/2019 17:57:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/08/2019 01:10:58	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/08/2019 09:18:36	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/08/2019 22:42:33	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
08/08/2019 17:08:23	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
09/08/2019 09:49:24	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/08/2019 11:01:31	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/08/2019 03:16:31	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/08/2019 14:44:13	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/08/2019 20:04:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/08/2019 15:47:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2019 00:26:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/08/2019 16:24:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
12/08/2019 18:55:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/08/2019 21:04:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/08/2019 21:08:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
12/08/2019 23:02:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/08/2019 09:41:09	Fire	Smoke/condensation	Steam	Hospital (P)
13/08/2019 13:00:32	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
13/08/2019 13:54:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/08/2019 15:50:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/08/2019 19:16:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/08/2019 21:46:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/08/2019 01:18:41	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/08/2019 06:34:18	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/08/2019 09:09:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/08/2019 12:48:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/08/2019 05:59:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/08/2019 11:24:17	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
15/08/2019 13:40:27	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
15/08/2019 15:20:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/08/2019 16:42:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/08/2019 22:58:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/08/2019 01:36:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/08/2019 08:59:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/08/2019 17:24:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/08/2019 19:41:59	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
17/08/2019 00:04:40	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/08/2019 08:09:19	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
17/08/2019 09:22:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/08/2019 13:10:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/08/2019 22:32:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/08/2019 03:45:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/08/2019 11:37:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/08/2019 12:46:02	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
18/08/2019 16:14:41	Fire	Smoke/condensation	Steam	Hospital (P)
19/08/2019 01:18:13	Fire alarm due to Apparatus	System: flame	Water intrusion	Hospital (P)
19/08/2019 11:06:19	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
19/08/2019 17:53:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/08/2019 10:22:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/08/2019 18:51:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/08/2019 23:01:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/08/2019 04:00:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/08/2019 09:09:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/08/2019 20:17:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/08/2019 16:03:55	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
22/08/2019 17:40:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/08/2019 06:28:12	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/08/2019 15:44:41	Fire	Smoke/condensation	Steam	Hospital (P)
23/08/2019 16:09:20	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/08/2019 19:30:14	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/08/2019 21:13:57	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/08/2019 21:56:28	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/08/2019 04:20:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/08/2019 17:29:41	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
24/08/2019 22:43:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/08/2019 00:55:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/08/2019 07:17:35	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
25/08/2019 15:15:13	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/08/2019 11:35:57	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/08/2019 17:42:47	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/08/2019 10:52:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/08/2019 13:58:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/08/2019 17:45:42	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/08/2019 09:06:10	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/08/2019 11:32:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/08/2019 18:29:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/08/2019 11:48:17	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
31/08/2019 06:53:09	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
31/08/2019 10:28:15	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
01/09/2019 21:41:48	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/09/2019 10:29:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/09/2019 18:18:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/09/2019 18:50:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/09/2019 16:26:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/09/2019 09:25:02	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
04/09/2019 13:29:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/09/2019 23:06:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/09/2019 08:28:40	Fire	Smell of burning	Overheating appliance	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
05/09/2019 19:21:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/09/2019 18:54:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/09/2019 08:02:05	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
07/09/2019 08:39:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/09/2019 08:14:15	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/09/2019 12:29:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/09/2019 20:41:15	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
09/09/2019 15:03:54	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
09/09/2019 15:16:03	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
09/09/2019 15:39:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/09/2019 06:07:37	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/09/2019 09:39:19	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/09/2019 20:35:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/09/2019 22:09:51	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
10/09/2019 23:02:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2019 23:15:38	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
11/09/2019 17:31:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/09/2019 16:16:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
12/09/2019 19:17:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/09/2019 00:45:22	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/09/2019 04:42:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/09/2019 19:13:48	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/09/2019 08:15:15	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/09/2019 14:06:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/09/2019 14:20:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/09/2019 03:31:49	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
17/09/2019 18:36:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/09/2019 23:30:31	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
19/09/2019 23:49:32	Fire	Smell of burning	Overheating appliance	Hospital (P)
20/09/2019 14:59:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/09/2019 21:49:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/09/2019 17:42:42	Fire	Smoke/condensation	Steam	Hospital (P)
22/09/2019 08:52:00	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
22/09/2019 21:06:39	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
23/09/2019 11:38:05	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/09/2019 14:25:04	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/09/2019 21:01:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/09/2019 00:58:51	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
24/09/2019 05:21:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/09/2019 07:47:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/09/2019 11:55:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/09/2019 13:08:32	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
25/09/2019 09:36:06	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/09/2019 10:49:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/09/2019 13:55:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/09/2019 14:36:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/09/2019 07:39:42	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/09/2019 11:57:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/09/2019 06:24:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/09/2019 11:52:25	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
27/09/2019 20:18:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/09/2019 23:30:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/09/2019 13:58:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/09/2019 15:38:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/09/2019 21:49:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/09/2019 01:28:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/09/2019 16:56:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/10/2019 18:00:54	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/10/2019 18:45:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/10/2019 19:01:55	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/10/2019 19:31:56	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
01/10/2019 20:24:29	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
02/10/2019 11:13:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/10/2019 16:22:50	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/10/2019 18:42:21	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
02/10/2019 18:45:58	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/10/2019 21:55:09	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
03/10/2019 10:06:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
03/10/2019 15:56:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/10/2019 16:07:26	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
04/10/2019 02:01:33	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
04/10/2019 12:43:52	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
05/10/2019 05:05:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/10/2019 00:22:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/10/2019 02:00:24	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
07/10/2019 02:52:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
07/10/2019 08:36:32	Good Intent false alarm	Fire	Bonfire not out of control	Hospital (P)
07/10/2019 10:28:19	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
07/10/2019 11:05:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/10/2019 22:36:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/10/2019 11:05:23	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/10/2019 11:59:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/10/2019 16:42:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/10/2019 18:07:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/10/2019 21:39:36	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/10/2019 23:27:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/10/2019 23:29:55	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
08/10/2019 23:43:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/10/2019 12:09:27	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/10/2019 13:19:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/10/2019 14:58:55	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/10/2019 17:56:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/10/2019 04:37:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/10/2019 07:05:38	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/10/2019 10:27:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/10/2019 06:28:59	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
11/10/2019 08:56:53	Fire	Smell of burning	Overheating appliance	Hospital (P)
11/10/2019 13:13:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/10/2019 14:37:11	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/10/2019 00:42:02	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
12/10/2019 08:28:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/10/2019 04:51:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/10/2019 05:27:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/10/2019 08:37:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/10/2019 08:40:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/10/2019 13:20:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/10/2019 14:34:54	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
14/10/2019 11:19:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/10/2019 20:40:44	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/10/2019 01:03:48	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
15/10/2019 02:32:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/10/2019 18:21:56	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/10/2019 10:19:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/10/2019 16:44:39	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/10/2019 03:31:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/10/2019 10:38:58	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/10/2019 10:50:43	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/10/2019 17:11:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/10/2019 06:05:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/10/2019 10:51:49	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/10/2019 22:38:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/10/2019 02:58:01	Fire alarm due to Apparatus	External Factors	Power surge	Hospital (P)
21/10/2019 06:55:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/10/2019 13:21:44	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
22/10/2019 14:13:32	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
22/10/2019 23:32:21	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/10/2019 06:21:43	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/10/2019 11:44:00	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/10/2019 12:17:35	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/10/2019 20:22:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/10/2019 00:38:04	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
24/10/2019 12:15:55	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
24/10/2019 20:12:35	Fire	Smoke/condensation	Steam	Hospital (P)
25/10/2019 09:28:48	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
25/10/2019 11:41:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/10/2019 11:48:02	Fire	Smell of burning	Overheating appliance	Hospital (P)
25/10/2019 22:00:27	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/10/2019 09:22:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/10/2019 20:40:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/10/2019 03:36:00	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
27/10/2019 07:05:20	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/10/2019 09:47:43	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/10/2019 11:23:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/10/2019 11:33:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/10/2019 15:18:40	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
28/10/2019 07:09:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/10/2019 07:46:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/10/2019 08:08:48	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/10/2019 04:39:06	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
29/10/2019 12:08:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/10/2019 18:16:05	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
29/10/2019 18:58:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
30/10/2019 08:52:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/10/2019 12:54:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/10/2019 17:19:27	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
30/10/2019 18:13:08	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
01/11/2019 01:21:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
01/11/2019 07:50:25	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/11/2019 13:40:19	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
01/11/2019 20:46:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/11/2019 23:28:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/11/2019 08:07:16	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
03/11/2019 19:34:23	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
04/11/2019 11:53:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/11/2019 18:10:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/11/2019 20:57:25	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/11/2019 06:17:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/11/2019 13:32:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/11/2019 17:49:36	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
05/11/2019 20:55:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/11/2019 04:29:29	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
07/11/2019 01:07:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/11/2019 10:13:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/11/2019 14:22:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/11/2019 20:19:25	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/11/2019 22:38:51	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
09/11/2019 05:25:56	Fire	Smoke/condensation	Steam	Hospital (P)
09/11/2019 10:00:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/11/2019 11:36:17	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/11/2019 07:20:39	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
11/11/2019 15:37:39	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
12/11/2019 04:05:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/11/2019 09:06:48	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
12/11/2019 09:30:39	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/11/2019 11:34:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/11/2019 14:57:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/11/2019 17:00:22	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/11/2019 17:26:54	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/11/2019 07:14:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/11/2019 19:34:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/11/2019 19:35:54	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
14/11/2019 20:18:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/11/2019 00:53:47	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
15/11/2019 06:23:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/11/2019 07:19:54	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
15/11/2019 12:12:30	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/11/2019 12:39:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/11/2019 18:36:36	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/11/2019 22:28:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/11/2019 12:29:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/11/2019 16:07:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/11/2019 15:00:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/11/2019 07:42:39	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
18/11/2019 08:09:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/11/2019 14:01:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/11/2019 06:10:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/11/2019 12:48:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/11/2019 21:12:23	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/11/2019 00:06:22	Fire	Smoke/condensation	Steam	Hospital (P)
20/11/2019 01:45:50	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
20/11/2019 11:47:51	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/11/2019 07:32:21	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
21/11/2019 10:28:19	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/11/2019 21:16:43	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
23/11/2019 16:10:23	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
24/11/2019 08:30:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/11/2019 14:26:01	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
24/11/2019 15:54:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/11/2019 17:00:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/11/2019 22:59:56	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
26/11/2019 02:31:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/11/2019 08:03:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/11/2019 14:22:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/11/2019 22:38:14	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/11/2019 08:05:59	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
27/11/2019 12:58:30	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/11/2019 17:28:13	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
28/11/2019 06:17:46	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
29/11/2019 01:06:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/11/2019 00:52:41	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
30/11/2019 13:19:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
30/11/2019 17:38:27	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
01/12/2019 09:32:55	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
01/12/2019 17:08:35	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/12/2019 21:17:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/12/2019 21:33:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/12/2019 20:41:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/12/2019 21:48:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/12/2019 08:33:46	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/12/2019 14:45:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/12/2019 08:04:05	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
04/12/2019 11:47:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/12/2019 21:26:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/12/2019 08:55:57	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/12/2019 09:24:16	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
05/12/2019 12:39:12	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
05/12/2019 15:28:56	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/12/2019 07:20:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/12/2019 11:50:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/12/2019 12:35:32	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
07/12/2019 23:57:06	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/12/2019 00:09:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/12/2019 08:12:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/12/2019 08:53:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/12/2019 12:58:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/12/2019 18:44:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/12/2019 23:18:15	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/12/2019 13:30:08	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/12/2019 08:14:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/12/2019 09:06:42	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/12/2019 20:36:41	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/12/2019 01:17:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/12/2019 03:19:03	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
12/12/2019 04:30:23	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/12/2019 10:49:22	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/12/2019 20:36:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/12/2019 05:11:16	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
13/12/2019 12:35:48	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
13/12/2019 15:50:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/12/2019 13:22:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/12/2019 23:49:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/12/2019 06:58:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/12/2019 08:59:53	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
15/12/2019 23:59:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/12/2019 16:51:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/12/2019 10:21:39	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
18/12/2019 16:43:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/12/2019 17:14:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/12/2019 01:47:20	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/12/2019 02:12:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/12/2019 02:43:17	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
19/12/2019 09:29:40	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
20/12/2019 11:43:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2019 13:22:47	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
20/12/2019 23:20:55	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
21/12/2019 17:15:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/12/2019 18:35:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/12/2019 21:35:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/12/2019 01:53:30	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
22/12/2019 17:20:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/12/2019 23:58:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/12/2019 06:19:47	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/12/2019 16:46:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/12/2019 11:18:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/12/2019 16:59:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/12/2019 17:25:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/12/2019 03:29:46	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
29/12/2019 12:17:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/12/2019 16:17:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/12/2019 19:49:36	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/12/2019 08:08:25	Fire alarm due to Apparatus	System: smoke alarm	Incorrect positioning	Hospital (P)
30/12/2019 23:00:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/12/2019 04:37:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/12/2019 05:32:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
31/12/2019 06:58:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/12/2019 12:15:41	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/01/2020 03:46:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/01/2020 15:32:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/01/2020 22:02:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
03/01/2020 10:24:35	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
03/01/2020 11:26:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/01/2020 18:38:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/01/2020 13:32:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/01/2020 16:04:24	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/01/2020 19:53:25	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/01/2020 10:47:37	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/01/2020 15:07:53	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/01/2020 16:49:17	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/01/2020 17:22:48	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/01/2020 19:29:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/01/2020 20:47:26	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/01/2020 08:21:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/01/2020 11:32:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/01/2020 14:17:11	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/01/2020 18:12:16	Fire	Smoke/condensation	Water intrusion	Hospital (P)
14/01/2020 13:29:03	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
14/01/2020 17:39:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/01/2020 01:06:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/01/2020 01:51:58	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/01/2020 23:35:24	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/01/2020 11:59:29	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/01/2020 08:58:38	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
18/01/2020 09:43:26	Fire	Smell of burning	Overheating appliance	Hospital (P)
18/01/2020 12:58:26	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/01/2020 18:12:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/01/2020 00:26:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/01/2020 16:55:26	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
20/01/2020 17:16:33	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
20/01/2020 19:02:44	Fire	Smoke/condensation	Steam	Hospital (P)
21/01/2020 12:13:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/01/2020 16:43:08	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
25/01/2020 11:30:00	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
25/01/2020 21:01:27	Fire alarm due to Apparatus	System: smoke alarm	Incorrect positioning	Hospital (P)
26/01/2020 00:28:01	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/01/2020 00:40:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/01/2020 02:11:07	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
26/01/2020 12:51:06	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
26/01/2020 13:52:02	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/01/2020 03:00:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/01/2020 14:10:01	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/01/2020 02:37:33	Fire alarm due to Apparatus	System: heat	Water intrusion	Hospital (P)
30/01/2020 12:10:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/01/2020 15:29:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/01/2020 17:56:52	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
01/02/2020 13:39:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/02/2020 02:43:44	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
03/02/2020 07:58:34	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
03/02/2020 09:25:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/02/2020 21:49:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/02/2020 10:34:16	Fire	Burnt toast/food	Other cooking	Hospital (P)
04/02/2020 18:28:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/02/2020 21:31:19	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
04/02/2020 23:46:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/02/2020 13:06:38	Fire	Burnt toast/food	Other cooking	Hospital (P)
05/02/2020 19:15:26	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/02/2020 15:04:05	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/02/2020 07:32:29	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/02/2020 05:14:31	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
08/02/2020 06:05:24	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
08/02/2020 14:48:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/02/2020 10:21:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/02/2020 17:20:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/02/2020 20:16:27	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
10/02/2020 01:06:13	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
10/02/2020 10:59:30	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/02/2020 06:47:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/02/2020 13:52:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/02/2020 14:30:16	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
11/02/2020 19:22:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/02/2020 15:30:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
13/02/2020 15:04:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/02/2020 20:06:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/02/2020 06:36:31	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/02/2020 09:06:58	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
14/02/2020 16:11:21	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
15/02/2020 05:53:33	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/02/2020 10:55:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/02/2020 23:04:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/02/2020 03:10:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/02/2020 05:11:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/02/2020 09:22:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/02/2020 10:55:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/02/2020 19:59:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/02/2020 15:28:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/02/2020 20:19:15	Good Intent false alarm	Fire	Security/Intruder alarm sounding	Hospital (P)
17/02/2020 22:19:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/02/2020 11:08:00	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
18/02/2020 13:41:54	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
18/02/2020 15:07:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/02/2020 15:10:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/02/2020 13:32:54	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
19/02/2020 13:37:28	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
19/02/2020 17:39:06	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
24/02/2020 09:08:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/02/2020 17:23:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/02/2020 18:11:02	Fire alarm due to Apparatus	External Factors	Bonfire outside building actuated fire alarm	Hospital (P)
24/02/2020 19:40:23	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/02/2020 22:07:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2020 16:13:08	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/02/2020 08:47:41	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/02/2020 15:36:33	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
27/02/2020 19:08:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/03/2020 08:33:50	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
04/03/2020 09:43:29	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
04/03/2020 11:43:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/03/2020 14:00:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/03/2020 18:32:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
05/03/2020 06:44:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/03/2020 17:04:29	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
06/03/2020 21:15:25	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
08/03/2020 00:56:42	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/03/2020 21:31:07	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/03/2020 10:08:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/03/2020 11:44:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/03/2020 12:37:35	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/03/2020 17:43:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/03/2020 18:23:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/03/2020 18:35:50	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/03/2020 15:15:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/03/2020 20:05:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/03/2020 07:19:35	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/03/2020 08:27:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/03/2020 17:00:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/03/2020 17:48:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/03/2020 06:16:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/03/2020 09:15:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/03/2020 18:27:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/03/2020 21:55:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/03/2020 10:03:33	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
18/03/2020 07:59:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/03/2020 19:57:34	Fire	Smoke/condensation	Steam	Hospital (P)
18/03/2020 22:24:32	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/03/2020 23:43:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/03/2020 11:43:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/03/2020 19:04:13	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
19/03/2020 19:31:23	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
20/03/2020 16:24:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
20/03/2020 17:33:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/03/2020 07:01:24	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
21/03/2020 11:51:18	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/03/2020 12:11:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/03/2020 03:23:33	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/03/2020 13:34:24	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
25/03/2020 01:04:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/03/2020 09:53:24	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
25/03/2020 15:01:49	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
26/03/2020 06:58:07	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/03/2020 21:53:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/03/2020 09:06:14	Fire alarm due to Apparatus	System: heat	Damaged system	Hospital (P)
29/03/2020 11:01:51	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/03/2020 12:32:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/03/2020 05:44:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/03/2020 02:00:11	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
31/03/2020 16:25:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/04/2020 12:28:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/04/2020 16:30:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/04/2020 15:41:04	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
05/04/2020 21:47:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2020 08:48:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/04/2020 11:16:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/04/2020 12:58:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/04/2020 13:17:53	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/04/2020 16:51:09	Fire	Smoke/condensation	Air conditioning	Hospital (P)
09/04/2020 08:32:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/04/2020 09:08:51	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
10/04/2020 18:17:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/04/2020 02:19:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/04/2020 07:24:45	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/04/2020 12:07:19	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/04/2020 14:16:01	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
14/04/2020 04:42:21	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/04/2020 11:30:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/04/2020 14:39:36	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/04/2020 19:43:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/04/2020 19:46:57	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
18/04/2020 08:33:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/04/2020 16:42:52	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
21/04/2020 02:36:31	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/04/2020 08:28:23	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
22/04/2020 03:57:57	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/04/2020 10:13:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/04/2020 12:24:07	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
27/04/2020 15:00:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/04/2020 08:12:33	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
28/04/2020 14:05:45	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/04/2020 18:26:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/04/2020 07:48:48	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
30/04/2020 10:45:32	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
01/05/2020 17:29:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/05/2020 09:07:46	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/05/2020 23:10:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/05/2020 02:55:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/05/2020 06:15:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/05/2020 09:32:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/05/2020 09:41:05	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/05/2020 12:04:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/05/2020 17:49:40	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
06/05/2020 20:49:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/05/2020 10:10:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/05/2020 09:55:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/05/2020 13:05:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/05/2020 13:23:49	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
08/05/2020 16:34:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/05/2020 16:37:42	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/05/2020 20:42:25	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
13/05/2020 21:47:23	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
14/05/2020 08:29:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/05/2020 08:55:59	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
16/05/2020 11:26:52	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/05/2020 19:13:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/05/2020 13:16:41	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
20/05/2020 18:43:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/05/2020 11:47:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/05/2020 22:20:45	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
22/05/2020 03:15:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/05/2020 11:30:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/05/2020 16:40:32	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
22/05/2020 18:10:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/05/2020 14:50:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/05/2020 10:07:43	Fire	Smell of burning	Overheating appliance	Hospital (P)
26/05/2020 01:29:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/05/2020 21:02:48	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
27/05/2020 14:56:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/05/2020 02:29:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/05/2020 08:40:54	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
28/05/2020 08:59:32	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
28/05/2020 21:20:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/05/2020 22:47:13	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
31/05/2020 01:32:22	Fire	Smoke/condensation	Steam	Hospital (P)
02/06/2020 07:14:36	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
02/06/2020 11:26:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/06/2020 01:36:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/06/2020 21:38:54	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
05/06/2020 02:33:04	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/06/2020 12:43:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/06/2020 13:35:56	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/06/2020 20:47:04	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
08/06/2020 08:48:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/06/2020 10:54:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/06/2020 22:02:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/06/2020 15:56:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/06/2020 07:40:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/06/2020 07:29:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/06/2020 12:15:38	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/06/2020 13:47:55	Fire	Smoke/condensation	Steam	Hospital (P)
12/06/2020 18:41:17	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/06/2020 19:35:08	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/06/2020 21:14:27	Fire	Smoke/condensation	Water intrusion	Hospital (P)
14/06/2020 15:59:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/06/2020 04:58:01	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
15/06/2020 07:26:09	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
16/06/2020 02:20:20	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/06/2020 12:20:06	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
18/06/2020 15:28:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/06/2020 15:50:14	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/06/2020 19:21:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/06/2020 10:11:55	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
20/06/2020 06:52:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/06/2020 19:57:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/06/2020 07:14:37	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
24/06/2020 08:24:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/06/2020 11:24:37	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
24/06/2020 14:43:32	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
24/06/2020 22:40:15	Fire	Smell of burning	Overheating appliance	Hospital (P)
25/06/2020 22:09:19	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
26/06/2020 04:32:30	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
26/06/2020 12:47:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/06/2020 13:34:06	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
26/06/2020 14:41:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/06/2020 15:52:40	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
28/06/2020 08:09:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/06/2020 13:38:48	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/06/2020 17:30:43	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/06/2020 07:14:05	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
29/06/2020 08:20:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/06/2020 14:28:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/06/2020 16:38:19	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
02/07/2020 06:04:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/07/2020 07:44:13	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
04/07/2020 08:05:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/07/2020 12:36:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/07/2020 10:38:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/07/2020 23:43:20	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
06/07/2020 06:58:16	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/07/2020 12:13:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/07/2020 16:59:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/07/2020 19:12:42	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/07/2020 05:54:49	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/07/2020 09:47:54	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/07/2020 22:21:23	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
09/07/2020 21:55:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/07/2020 06:35:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/07/2020 11:11:30	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/07/2020 11:20:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/07/2020 13:15:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/07/2020 15:40:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/07/2020 01:54:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/07/2020 20:08:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
11/07/2020 22:35:23	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
12/07/2020 09:47:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/07/2020 11:41:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/07/2020 18:29:55	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
13/07/2020 07:07:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/07/2020 00:59:50	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
14/07/2020 03:31:23	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
14/07/2020 08:40:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/07/2020 18:44:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/07/2020 08:17:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/07/2020 19:53:38	Fire	Smoke/condensation	Steam	Hospital (P)
18/07/2020 10:55:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
19/07/2020 15:19:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/07/2020 09:35:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/07/2020 21:35:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/07/2020 00:07:30	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/07/2020 01:30:53	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/07/2020 18:33:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/07/2020 12:33:20	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
25/07/2020 12:39:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/07/2020 23:15:42	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
27/07/2020 09:36:35	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
28/07/2020 10:42:11	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
28/07/2020 10:48:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2020 02:07:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/07/2020 07:56:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/07/2020 16:42:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2020 19:17:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/07/2020 15:39:25	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
30/07/2020 21:17:28	Fire	Smell of burning	Overheating appliance	Hospital (P)
31/07/2020 16:53:56	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/08/2020 14:08:13	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
03/08/2020 14:17:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/08/2020 17:48:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/08/2020 12:31:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/08/2020 16:50:35	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
06/08/2020 03:07:48	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/08/2020 23:54:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/08/2020 08:55:40	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
07/08/2020 10:49:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/08/2020 04:29:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/08/2020 08:27:47	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
09/08/2020 00:41:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/08/2020 11:02:56	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/08/2020 20:39:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/08/2020 21:11:13	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
10/08/2020 07:49:02	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/08/2020 09:22:14	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
10/08/2020 15:04:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/08/2020 01:29:16	Good Intent false alarm	Fire	Security/Intruder alarm sounding	Hospital (P)
12/08/2020 08:44:18	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
12/08/2020 13:08:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2020 13:18:46	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
13/08/2020 08:02:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/08/2020 19:18:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/08/2020 23:48:18	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
14/08/2020 06:48:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/08/2020 11:17:01	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
15/08/2020 11:13:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/08/2020 12:15:30	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/08/2020 02:53:09	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/08/2020 08:15:23	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/08/2020 09:27:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/08/2020 13:37:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/08/2020 14:46:07	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
16/08/2020 20:51:25	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
17/08/2020 04:38:40	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
18/08/2020 17:28:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2020 03:12:22	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2020 04:39:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2020 06:08:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2020 20:40:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2020 21:02:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/08/2020 23:23:25	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/08/2020 02:43:24	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
20/08/2020 10:50:44	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
21/08/2020 11:55:20	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
21/08/2020 17:50:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/08/2020 08:32:02	Fire alarm due to Apparatus	System: heat	Unsuitable equipment	Hospital (P)
22/08/2020 10:39:00	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
22/08/2020 20:38:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/08/2020 08:59:46	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
25/08/2020 06:07:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/08/2020 13:00:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/08/2020 16:14:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/08/2020 17:44:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/08/2020 17:58:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/08/2020 18:05:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/08/2020 09:44:09	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
27/08/2020 12:12:19	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
27/08/2020 17:58:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/08/2020 19:38:31	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/08/2020 14:39:25	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
28/08/2020 15:31:46	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
29/08/2020 12:01:08	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/08/2020 07:06:47	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
31/08/2020 10:45:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/09/2020 04:01:12	Fire alarm due to Apparatus	System: heat	Poor maintenance of system	Hospital (P)
01/09/2020 12:30:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/09/2020 21:43:05	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/09/2020 11:41:16	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
03/09/2020 22:53:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/09/2020 06:18:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/09/2020 12:15:32	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
06/09/2020 17:47:55	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
08/09/2020 00:05:13	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
08/09/2020 10:45:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/09/2020 21:02:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/09/2020 10:30:07	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
11/09/2020 14:57:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/09/2020 11:24:12	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/09/2020 11:02:18	Fire alarm due to Apparatus	System: heat	Damaged system	Hospital (P)
15/09/2020 11:04:37	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/09/2020 18:19:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/09/2020 20:01:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/09/2020 09:02:04	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/09/2020 15:50:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/09/2020 07:17:54	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
17/09/2020 10:40:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/09/2020 16:14:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/09/2020 20:54:30	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/09/2020 12:14:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/09/2020 11:54:13	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/09/2020 12:05:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/09/2020 12:22:16	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
22/09/2020 09:07:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/09/2020 10:02:06	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
22/09/2020 15:21:29	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/09/2020 15:12:16	Fire	Smell of burning	Overheating appliance	Hospital (P)
24/09/2020 02:17:07	Malicious False Alarm	Malicious False Alarm	Malicious call to an incident - other	Hospital (P)
24/09/2020 08:13:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/09/2020 20:47:05	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/09/2020 03:22:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
26/09/2020 08:10:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/09/2020 11:03:44	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/09/2020 00:38:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/09/2020 07:21:40	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
27/09/2020 09:07:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/09/2020 22:08:23	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
29/09/2020 00:37:45	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/10/2020 00:24:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/10/2020 10:38:25	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/10/2020 14:16:08	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/10/2020 04:46:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/10/2020 15:28:31	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/10/2020 00:25:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/10/2020 07:18:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/10/2020 14:41:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/10/2020 15:30:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/10/2020 09:59:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
09/10/2020 07:44:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/10/2020 08:55:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
09/10/2020 15:17:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/10/2020 23:16:02	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
10/10/2020 10:37:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/10/2020 17:34:47	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
14/10/2020 14:13:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/10/2020 15:36:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/10/2020 23:34:29	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
15/10/2020 11:44:13	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
15/10/2020 20:12:56	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/10/2020 08:48:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/10/2020 22:09:10	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
17/10/2020 14:43:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/10/2020 20:05:45	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
18/10/2020 06:36:00	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
20/10/2020 06:34:21	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
20/10/2020 11:17:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
20/10/2020 17:35:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/10/2020 17:43:07	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/10/2020 19:37:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/10/2020 19:48:58	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
22/10/2020 06:38:30	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
22/10/2020 13:59:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
22/10/2020 15:22:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/10/2020 14:12:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/10/2020 08:51:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/10/2020 01:29:11	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
27/10/2020 10:30:59	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
27/10/2020 13:21:56	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/10/2020 21:18:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/10/2020 09:49:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
29/10/2020 18:46:44	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
29/10/2020 22:15:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/10/2020 17:41:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/11/2020 15:15:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/11/2020 17:07:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/11/2020 21:35:18	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
04/11/2020 12:22:56	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
04/11/2020 14:04:23	Fire	Smoke/condensation	Steam	Hospital (P)
04/11/2020 19:26:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/11/2020 03:34:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/11/2020 08:20:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/11/2020 14:03:13	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
05/11/2020 17:04:05	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
05/11/2020 19:57:26	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/11/2020 19:58:12	Good Intent false alarm	Good Intent false alarm	Special Service - Brigade action not required	Hospital (P)
05/11/2020 20:06:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/11/2020 07:42:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/11/2020 01:03:46	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
07/11/2020 11:04:20	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
08/11/2020 07:37:28	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/11/2020 15:11:13	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/11/2020 15:57:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/11/2020 17:20:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/11/2020 12:11:56	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/11/2020 18:41:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/11/2020 21:46:49	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
11/11/2020 23:19:57	Fire alarm due to Apparatus	External Factors	Storm/Weather conditions	Hospital (P)
13/11/2020 05:18:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/11/2020 16:45:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/11/2020 21:47:39	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
14/11/2020 23:59:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/11/2020 19:10:01	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
17/11/2020 09:36:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/11/2020 12:14:01	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
17/11/2020 17:54:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/11/2020 12:25:35	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/11/2020 13:46:40	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/11/2020 19:32:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/11/2020 22:53:32	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
19/11/2020 12:40:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/11/2020 13:50:45	Fire	Smell of burning	Overheating appliance	Hospital (P)
22/11/2020 04:31:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/11/2020 14:59:32	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/11/2020 06:16:00	Fire alarm due to Apparatus	System: heat	Alarm actuated - Other reason	Hospital (P)
23/11/2020 06:23:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/11/2020 06:34:34	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
23/11/2020 09:09:20	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/11/2020 14:31:32	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/11/2020 15:01:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/11/2020 10:05:18	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
26/11/2020 09:20:00	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
27/11/2020 01:27:17	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
27/11/2020 02:55:16	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/11/2020 10:41:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/11/2020 19:37:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
27/11/2020 23:03:06	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
28/11/2020 12:28:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/11/2020 16:48:08	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
28/11/2020 21:12:37	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
29/11/2020 10:27:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/11/2020 11:53:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/11/2020 13:56:11	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
30/11/2020 23:12:53	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
01/12/2020 07:39:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/12/2020 11:06:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/12/2020 16:00:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/12/2020 23:05:50	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
01/12/2020 23:55:17	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/12/2020 00:39:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/12/2020 17:40:25	Fire	Smell of burning	Overheating appliance	Hospital (P)
03/12/2020 14:38:43	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/12/2020 15:57:58	Fire alarm due to Apparatus	System: other	Unsuitable equipment	Hospital (P)
03/12/2020 17:58:55	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
03/12/2020 21:40:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/12/2020 16:00:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/12/2020 21:09:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/12/2020 16:53:36	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
06/12/2020 20:32:06	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/12/2020 03:58:52	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
07/12/2020 06:34:39	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
07/12/2020 12:41:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/12/2020 16:28:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/12/2020 19:23:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/12/2020 11:25:14	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
09/12/2020 20:26:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/12/2020 22:05:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/12/2020 12:09:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/12/2020 13:44:09	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/12/2020 20:20:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/12/2020 09:47:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/12/2020 11:51:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/12/2020 10:47:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/12/2020 14:53:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/12/2020 16:25:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/12/2020 19:42:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/12/2020 09:31:48	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/12/2020 10:12:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/12/2020 22:41:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/12/2020 04:44:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/12/2020 14:02:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/12/2020 23:24:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/12/2020 22:21:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/12/2020 00:53:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/12/2020 11:05:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/12/2020 16:37:54	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/12/2020 19:17:13	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
24/12/2020 00:22:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/12/2020 16:13:13	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/12/2020 18:46:29	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/12/2020 04:35:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/12/2020 02:19:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/12/2020 21:09:26	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
30/12/2020 03:04:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/12/2020 21:54:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/12/2020 10:27:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/12/2020 20:19:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/01/2021 16:16:01	Fire	Smoke/condensation	Smoking chimney	Hospital (P)
02/01/2021 08:55:18	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/01/2021 01:49:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/01/2021 08:15:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
04/01/2021 09:02:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/01/2021 09:32:36	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
04/01/2021 10:31:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/01/2021 14:35:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/01/2021 06:17:00	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
07/01/2021 11:26:43	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
08/01/2021 17:44:42	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
09/01/2021 04:15:24	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/01/2021 16:53:34	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
11/01/2021 20:51:19	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
12/01/2021 13:25:12	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
13/01/2021 03:58:55	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
13/01/2021 17:57:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/01/2021 21:24:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2021 12:00:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2021 16:28:15	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/01/2021 13:35:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/01/2021 09:35:52	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/01/2021 02:24:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/01/2021 07:37:53	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
18/01/2021 14:04:49	Malicious False Alarm	Malicious False Alarm	Malicious call to an incident - other	Hospital (P)
19/01/2021 14:45:52	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
20/01/2021 06:39:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/01/2021 12:32:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/01/2021 07:46:23	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/01/2021 08:33:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/01/2021 10:59:08	Fire alarm due to Apparatus	System: smoke alarm	Unsuitable equipment	Hospital (P)
22/01/2021 07:30:51	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
22/01/2021 10:54:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/01/2021 18:16:53	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
24/01/2021 01:13:30	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/01/2021 20:30:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/01/2021 23:05:52	Fire	Smoke/condensation	Steam	Hospital (P)
25/01/2021 09:48:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/01/2021 11:15:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/01/2021 16:01:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/01/2021 17:39:27	Fire	Smoke/condensation	Steam	Hospital (P)
27/01/2021 06:31:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/01/2021 00:57:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/01/2021 04:00:00	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
28/01/2021 05:50:01	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
28/01/2021 11:24:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/01/2021 12:00:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/01/2021 07:19:34	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
29/01/2021 22:26:57	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/01/2021 08:21:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/01/2021 09:27:06	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/01/2021 10:19:35	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
30/01/2021 10:45:34	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
31/01/2021 23:46:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/02/2021 03:27:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/02/2021 07:29:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/02/2021 11:13:36	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
02/02/2021 00:29:03	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
03/02/2021 07:57:19	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
04/02/2021 08:51:52	Fire alarm due to Apparatus	System: sprinkler	Poor maintenance of system	Hospital (P)
05/02/2021 12:48:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/02/2021 18:12:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/02/2021 08:51:55	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
07/02/2021 12:25:14	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/02/2021 14:45:26	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/02/2021 21:07:52	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/02/2021 23:16:24	Fire alarm due to Apparatus	System: heat	Water intrusion	Hospital (P)
07/02/2021 23:18:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/02/2021 06:19:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/02/2021 15:00:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/02/2021 01:36:21	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/02/2021 01:37:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/02/2021 06:34:44	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/02/2021 12:27:21	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
09/02/2021 18:21:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/02/2021 08:21:48	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/02/2021 13:38:06	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/02/2021 17:47:57	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/02/2021 09:50:43	Fire	Smoke/condensation	Air conditioning	Hospital (P)
11/02/2021 11:27:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/02/2021 21:30:57	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/02/2021 22:02:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
11/02/2021 22:43:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/02/2021 00:42:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/02/2021 02:08:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/02/2021 17:00:50	Good Intent false alarm	Fire	Reflected light/sun-light	Hospital (P)
12/02/2021 23:04:47	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/02/2021 10:58:19	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/02/2021 13:37:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/02/2021 17:54:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/02/2021 19:06:48	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/02/2021 18:02:53	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
18/02/2021 20:08:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/02/2021 01:43:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/02/2021 08:12:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/02/2021 10:37:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/02/2021 05:54:40	Fire alarm due to Apparatus	System: other	Alarm actuated - Other reason	Hospital (P)
22/02/2021 07:42:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/02/2021 16:40:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/02/2021 08:28:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/02/2021 09:15:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/02/2021 11:16:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/02/2021 12:02:10	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/02/2021 17:41:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/02/2021 02:48:50	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
24/02/2021 03:45:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/02/2021 04:46:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/02/2021 07:07:08	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/02/2021 11:19:17	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/02/2021 19:47:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/02/2021 12:27:22	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/02/2021 17:32:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2021 00:35:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2021 04:36:58	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/02/2021 11:16:14	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
26/02/2021 19:50:30	Fire	Smell of burning	Overheating appliance	Hospital (P)
27/02/2021 22:34:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/02/2021 03:28:45	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/03/2021 00:52:25	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/03/2021 11:08:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/03/2021 14:21:59	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
01/03/2021 20:37:05	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
02/03/2021 07:57:33	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/03/2021 09:35:50	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/03/2021 18:45:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/03/2021 02:09:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/03/2021 08:25:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/03/2021 16:25:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/03/2021 12:50:27	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
05/03/2021 09:29:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/03/2021 22:25:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/03/2021 09:39:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/03/2021 11:34:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/03/2021 23:49:15	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/03/2021 13:18:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/03/2021 14:06:13	Fire alarm due to Apparatus	Contaminants	Thrips/Small insects	Hospital (P)
07/03/2021 15:34:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/03/2021 14:22:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/03/2021 18:05:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/03/2021 02:11:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/03/2021 11:04:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/03/2021 15:00:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/03/2021 09:28:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/03/2021 22:03:08	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
11/03/2021 17:59:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/03/2021 08:52:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/03/2021 10:57:50	Fire alarm due to Apparatus	System: heat	Alarm actuated - Other reason	Hospital (P)
13/03/2021 08:52:28	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
13/03/2021 09:04:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/03/2021 09:17:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/03/2021 14:47:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/03/2021 19:25:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/03/2021 07:34:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/03/2021 17:53:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/03/2021 17:40:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/03/2021 14:22:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/03/2021 17:42:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/03/2021 23:14:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
21/03/2021 12:51:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/03/2021 21:17:28	Good Intent false alarm	Good Intent false alarm	Special Service - Brigade action not required	Hospital (P)
23/03/2021 07:47:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/03/2021 10:35:56	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
23/03/2021 12:23:29	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/03/2021 14:21:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/03/2021 06:17:49	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/03/2021 08:55:36	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
24/03/2021 15:32:53	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
24/03/2021 18:59:50	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/03/2021 20:30:28	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/03/2021 21:38:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/03/2021 18:59:49	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/03/2021 09:59:45	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
26/03/2021 10:35:11	Fire	Smoke/condensation	Steam	Hospital (P)
26/03/2021 17:53:42	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/03/2021 09:55:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/03/2021 17:52:01	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/03/2021 00:51:06	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/03/2021 05:01:51	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
28/03/2021 11:59:06	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/03/2021 07:58:26	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/03/2021 08:24:16	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/03/2021 07:54:12	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/03/2021 10:12:14	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/03/2021 10:33:10	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
31/03/2021 17:45:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/04/2021 07:59:11	Fire	Smell of burning	Overheating appliance	Hospital (P)
02/04/2021 15:27:56	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/04/2021 22:36:30	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
03/04/2021 21:21:38	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
03/04/2021 21:26:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/04/2021 04:33:57	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
05/04/2021 16:04:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/04/2021 16:19:11	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/04/2021 18:40:45	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
07/04/2021 19:24:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/04/2021 07:49:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/04/2021 15:45:22	Fire	Smell of burning	Overheating appliance	Hospital (P)
10/04/2021 16:18:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/04/2021 05:16:52	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
12/04/2021 09:18:37	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/04/2021 08:46:59	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/04/2021 08:25:16	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
15/04/2021 10:57:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/04/2021 14:55:39	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/04/2021 17:34:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/04/2021 07:40:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/04/2021 02:28:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/04/2021 08:59:34	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
19/04/2021 13:32:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/04/2021 21:30:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/04/2021 14:47:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/04/2021 21:01:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/04/2021 02:00:20	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
21/04/2021 05:38:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2021 21:21:53	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
22/04/2021 08:06:57	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
22/04/2021 11:02:03	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
22/04/2021 15:53:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/04/2021 18:45:58	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
22/04/2021 23:40:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/04/2021 22:52:54	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/04/2021 03:41:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/04/2021 22:27:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2021 10:38:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/04/2021 15:45:31	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
26/04/2021 09:12:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/04/2021 23:35:15	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
28/04/2021 14:54:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/04/2021 16:04:24	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
28/04/2021 19:25:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/04/2021 20:22:05	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/04/2021 00:44:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
29/04/2021 02:29:18	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/04/2021 03:59:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
29/04/2021 15:04:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/04/2021 17:54:02	Fire	Burnt toast/food	Barbeque not out of control	Hospital (P)
29/04/2021 21:30:56	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
01/05/2021 11:01:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/05/2021 06:50:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/05/2021 17:46:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/05/2021 07:08:33	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/05/2021 10:12:32	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
04/05/2021 13:14:37	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/05/2021 12:13:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
06/05/2021 13:16:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/05/2021 17:44:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/05/2021 16:37:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/05/2021 15:17:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/05/2021 02:12:58	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/05/2021 11:19:34	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
11/05/2021 15:23:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/05/2021 10:08:35	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
12/05/2021 23:32:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/05/2021 08:02:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/05/2021 09:08:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/05/2021 13:37:50	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
17/05/2021 01:20:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/05/2021 17:44:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/05/2021 06:20:26	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/05/2021 07:31:20	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
20/05/2021 07:46:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/05/2021 08:34:14	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/05/2021 09:16:17	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/05/2021 20:10:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/05/2021 05:40:40	Fire	Smell of burning	Overheating appliance	Hospital (P)
24/05/2021 11:24:16	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
25/05/2021 21:21:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/05/2021 01:25:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/05/2021 03:32:31	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
27/05/2021 15:27:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/05/2021 09:24:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/05/2021 00:00:26	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
31/05/2021 05:30:58	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
01/06/2021 05:57:16	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/06/2021 14:07:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/06/2021 09:48:49	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
03/06/2021 01:47:29	Fire alarm due to Apparatus	Contaminants	Thrips/Small insects	Hospital (P)
03/06/2021 05:25:55	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
03/06/2021 12:28:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/06/2021 16:18:06	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/06/2021 09:12:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/06/2021 14:00:38	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/06/2021 16:03:58	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
05/06/2021 09:35:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/06/2021 11:42:55	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
05/06/2021 12:33:19	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
06/06/2021 05:18:51	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/06/2021 07:19:25	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/06/2021 16:33:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/06/2021 07:42:40	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/06/2021 10:20:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/06/2021 23:28:46	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/06/2021 10:03:46	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/06/2021 14:32:25	Fire alarm due to Apparatus	System: heat	Alarm actuated - Other reason	Hospital (P)
08/06/2021 16:29:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/06/2021 17:47:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/06/2021 14:16:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/06/2021 14:42:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/06/2021 18:26:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/06/2021 14:33:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/06/2021 22:49:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/06/2021 13:36:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/06/2021 13:46:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/06/2021 19:54:43	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/06/2021 11:13:38	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
15/06/2021 22:03:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/06/2021 04:54:50	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
16/06/2021 14:18:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/06/2021 15:49:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/06/2021 16:17:00	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
17/06/2021 22:56:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/06/2021 02:31:29	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
18/06/2021 14:52:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/06/2021 18:03:17	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
18/06/2021 23:04:40	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
19/06/2021 08:59:47	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
19/06/2021 15:14:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/06/2021 10:11:47	Fire alarm due to Apparatus	System: flame	Alarm actuated - Other reason	Hospital (P)
21/06/2021 12:19:37	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/06/2021 20:33:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/06/2021 07:24:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/06/2021 11:21:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/06/2021 13:47:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/06/2021 17:03:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/06/2021 07:03:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/06/2021 22:02:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/06/2021 04:22:13	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
25/06/2021 08:33:29	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
25/06/2021 11:50:21	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/06/2021 10:20:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/06/2021 18:18:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/06/2021 02:28:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/06/2021 14:00:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/06/2021 22:51:13	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/06/2021 19:18:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/06/2021 20:43:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/06/2021 07:31:29	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
29/06/2021 17:56:26	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/06/2021 01:38:30	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/06/2021 12:42:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/06/2021 15:44:52	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/07/2021 20:40:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/07/2021 14:19:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/07/2021 19:23:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/07/2021 19:43:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/07/2021 16:57:52	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/07/2021 22:55:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/07/2021 23:31:05	Good Intent false alarm	Good Intent false alarm	Call to special service - No incident at reported location	Hospital (P)
07/07/2021 14:44:31	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
09/07/2021 17:26:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/07/2021 19:05:39	Fire	Burnt toast/food	Other cooking	Hospital (P)
10/07/2021 10:22:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/07/2021 12:00:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/07/2021 16:53:08	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/07/2021 18:37:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/07/2021 17:19:05	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
12/07/2021 23:01:36	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
13/07/2021 01:40:34	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/07/2021 11:17:36	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/07/2021 16:00:30	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
15/07/2021 09:07:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/07/2021 21:02:51	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
16/07/2021 09:28:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/07/2021 09:36:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/07/2021 23:12:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/07/2021 12:52:28	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
17/07/2021 14:28:47	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/07/2021 15:20:34	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/07/2021 04:41:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/07/2021 15:39:36	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
19/07/2021 16:59:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
19/07/2021 17:43:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/07/2021 18:15:13	Malicious False Alarm	Malicious False Alarm	Malicious call to an incident - other	Hospital (P)
20/07/2021 22:05:58	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
20/07/2021 22:41:53	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
21/07/2021 15:51:48	Fire alarm due to Apparatus	System: heat	Incorrect positioning	Hospital (P)
21/07/2021 19:04:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/07/2021 20:27:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
22/07/2021 00:39:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/07/2021 10:27:42	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/07/2021 15:17:16	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/07/2021 15:39:33	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/07/2021 10:10:20	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
24/07/2021 11:53:13	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/07/2021 14:22:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/07/2021 06:26:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
27/07/2021 14:29:00	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/07/2021 01:23:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
30/07/2021 04:46:36	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
31/07/2021 12:26:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/08/2021 04:28:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/08/2021 05:05:01	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/08/2021 08:05:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/08/2021 20:57:39	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
03/08/2021 07:57:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
03/08/2021 09:23:42	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/08/2021 11:07:06	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
03/08/2021 13:04:22	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
03/08/2021 20:25:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/08/2021 12:19:43	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
05/08/2021 03:38:45	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/08/2021 15:51:47	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/08/2021 11:06:39	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/08/2021 19:45:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/08/2021 07:14:47	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/08/2021 11:05:56	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/08/2021 10:22:23	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
10/08/2021 11:32:17	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/08/2021 17:17:16	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/08/2021 17:43:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/08/2021 08:54:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/08/2021 15:20:51	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/08/2021 22:22:20	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/08/2021 09:21:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2021 11:19:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2021 12:20:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/08/2021 23:28:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/08/2021 09:08:55	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
17/08/2021 08:25:28	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/08/2021 15:41:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/08/2021 08:21:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/08/2021 16:21:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/08/2021 20:16:53	Fire	Smell of burning	Overheating appliance	Hospital (P)
19/08/2021 10:25:41	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
19/08/2021 14:08:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/08/2021 10:33:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/08/2021 13:06:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/08/2021 19:39:29	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/08/2021 16:39:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/08/2021 20:28:27	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/08/2021 01:17:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/08/2021 05:37:07	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/08/2021 15:05:02	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
26/08/2021 12:19:03	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/08/2021 23:10:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/08/2021 07:24:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/08/2021 11:02:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/08/2021 02:47:17	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/08/2021 02:58:52	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
29/08/2021 18:16:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/08/2021 19:53:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/09/2021 05:07:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/09/2021 11:14:30	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
01/09/2021 12:33:20	Fire alarm due to Apparatus	System: other	Damaged system	Hospital (P)
03/09/2021 06:45:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
03/09/2021 17:44:36	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
04/09/2021 07:20:45	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
04/09/2021 13:31:50	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/09/2021 00:18:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/09/2021 13:42:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/09/2021 06:41:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/09/2021 09:45:20	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/09/2021 16:35:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/09/2021 19:04:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/09/2021 19:38:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
07/09/2021 11:11:25	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
07/09/2021 12:28:04	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/09/2021 13:37:24	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
07/09/2021 15:00:06	Fire	Smoke/condensation	Steam	Hospital (P)
07/09/2021 20:05:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/09/2021 21:48:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/09/2021 04:56:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
09/09/2021 15:17:37	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
11/09/2021 13:50:18	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/09/2021 18:32:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/09/2021 01:02:21	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/09/2021 05:57:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/09/2021 04:41:28	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/09/2021 17:16:38	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
17/09/2021 06:22:03	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/09/2021 19:29:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
18/09/2021 09:01:09	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/09/2021 09:32:38	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/09/2021 19:01:48	Good Intent false alarm	Fire	Reflected light/sun-light	Hospital (P)
19/09/2021 05:25:11	Fire alarm due to Apparatus	System: heat	Alarm actuated - Other reason	Hospital (P)
20/09/2021 21:41:24	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
21/09/2021 10:02:24	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/09/2021 12:29:59	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
21/09/2021 15:33:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/09/2021 21:19:26	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
21/09/2021 22:10:41	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
22/09/2021 10:21:44	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
22/09/2021 19:05:22	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/09/2021 02:35:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/09/2021 10:00:02	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/09/2021 13:10:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/09/2021 17:19:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
23/09/2021 18:11:49	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/09/2021 23:14:35	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/09/2021 09:47:15	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
24/09/2021 20:20:54	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
25/09/2021 11:43:48	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
25/09/2021 18:46:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/09/2021 19:11:31	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/09/2021 21:35:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/09/2021 08:31:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/09/2021 09:08:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/09/2021 22:47:35	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
29/09/2021 00:42:01	Fire	Smell of burning	Overheating appliance	Hospital (P)
29/09/2021 08:53:36	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/09/2021 02:55:11	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/09/2021 08:33:31	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/09/2021 09:59:38	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
30/09/2021 13:51:53	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/09/2021 14:02:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/09/2021 16:54:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
30/09/2021 18:12:52	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
01/10/2021 04:38:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/10/2021 10:48:15	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/10/2021 13:03:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/10/2021 05:15:18	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
03/10/2021 09:05:05	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
03/10/2021 22:27:36	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
03/10/2021 23:20:04	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/10/2021 06:32:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/10/2021 09:56:47	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/10/2021 13:34:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/10/2021 18:46:18	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
05/10/2021 10:38:05	Good Intent false alarm	Fire	Security/Intruder alarm sounding	Hospital (P)
05/10/2021 20:42:49	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
06/10/2021 04:07:34	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/10/2021 07:46:53	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/10/2021 09:53:23	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
07/10/2021 17:59:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/10/2021 18:48:15	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
08/10/2021 01:00:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/10/2021 11:53:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/10/2021 12:27:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/10/2021 17:09:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/10/2021 18:39:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/10/2021 19:37:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/10/2021 18:32:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/10/2021 10:40:13	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
10/10/2021 11:22:24	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/10/2021 17:23:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/10/2021 10:55:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/10/2021 11:46:21	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/10/2021 12:16:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
15/10/2021 11:33:48	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
17/10/2021 20:24:22	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/10/2021 22:24:18	Fire	Smell of burning	Overheating appliance	Hospital (P)
18/10/2021 06:02:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/10/2021 14:37:35	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/10/2021 17:02:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/10/2021 20:02:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/10/2021 11:15:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/10/2021 12:20:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/10/2021 08:40:34	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
22/10/2021 11:45:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/10/2021 18:16:37	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
22/10/2021 18:48:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/10/2021 18:38:38	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
25/10/2021 08:52:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/10/2021 23:53:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/10/2021 07:27:43	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/10/2021 11:34:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/10/2021 22:52:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/10/2021 03:24:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/10/2021 03:57:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/10/2021 10:34:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/10/2021 13:36:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/10/2021 16:20:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/10/2021 00:00:09	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/11/2021 12:35:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/11/2021 12:38:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/11/2021 15:07:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/11/2021 03:35:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/11/2021 09:39:40	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/11/2021 00:56:29	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/11/2021 16:16:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/11/2021 20:47:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/11/2021 11:58:33	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/11/2021 15:07:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/11/2021 00:41:46	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/11/2021 01:13:05	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/11/2021 22:19:45	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/11/2021 14:21:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/11/2021 18:23:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/11/2021 21:14:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/11/2021 19:51:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/11/2021 23:03:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/11/2021 02:38:28	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
13/11/2021 07:42:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/11/2021 14:53:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/11/2021 08:29:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/11/2021 08:49:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/11/2021 13:36:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/11/2021 22:42:42	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/11/2021 08:25:17	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/11/2021 19:25:19	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
16/11/2021 20:56:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/11/2021 13:25:09	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
18/11/2021 11:50:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
18/11/2021 17:24:43	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
18/11/2021 18:51:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/11/2021 08:10:27	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/11/2021 22:39:22	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/11/2021 12:58:19	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
22/11/2021 17:55:52	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/11/2021 09:52:13	Fire	Smoke/condensation	Fumes/heat haze	Hospital (P)
24/11/2021 13:41:31	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
25/11/2021 12:31:38	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
27/11/2021 01:54:27	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/11/2021 09:36:41	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
27/11/2021 11:08:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/11/2021 15:39:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/11/2021 15:53:04	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
28/11/2021 09:11:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/11/2021 10:12:01	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
28/11/2021 21:42:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/11/2021 23:05:12	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/11/2021 20:33:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/11/2021 20:44:58	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
29/11/2021 22:07:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
30/11/2021 00:59:27	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
30/11/2021 09:38:50	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/11/2021 22:21:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
01/12/2021 07:20:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/12/2021 03:52:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/12/2021 15:29:12	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/12/2021 17:50:42	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
05/12/2021 00:52:17	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
05/12/2021 07:01:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/12/2021 08:04:10	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/12/2021 20:04:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/12/2021 08:29:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/12/2021 03:57:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/12/2021 13:24:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/12/2021 16:41:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/12/2021 22:38:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/12/2021 12:17:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/12/2021 15:18:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/12/2021 04:40:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/12/2021 07:15:34	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/12/2021 11:13:12	Fire	Smoke/condensation	Steam	Hospital (P)
10/12/2021 13:09:50	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/12/2021 13:15:37	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
12/12/2021 09:58:37	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
12/12/2021 17:53:02	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
13/12/2021 16:08:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/12/2021 16:47:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/12/2021 19:11:25	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
14/12/2021 14:38:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/12/2021 03:48:57	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/12/2021 09:17:01	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/12/2021 11:12:01	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/12/2021 20:48:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/12/2021 15:45:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/12/2021 17:30:15	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/12/2021 05:04:51	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/12/2021 11:57:26	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
17/12/2021 21:01:09	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
18/12/2021 03:50:37	Fire	Smell of burning	Overheating appliance	Hospital (P)
20/12/2021 02:43:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2021 02:57:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2021 18:13:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/12/2021 10:14:57	Fire alarm due to Apparatus	System: sprinkler	Damaged system	Hospital (P)
21/12/2021 14:17:53	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
22/12/2021 07:57:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/12/2021 07:58:54	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/12/2021 01:30:54	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
23/12/2021 03:35:41	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/12/2021 13:31:34	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
23/12/2021 19:21:02	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/12/2021 06:53:00	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
24/12/2021 11:31:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/12/2021 13:40:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
25/12/2021 00:12:02	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
25/12/2021 17:44:13	Fire	Smoke/condensation	Steam	Hospital (P)
26/12/2021 00:19:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/12/2021 09:03:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/12/2021 00:41:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/01/2022 19:25:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/01/2022 15:27:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/01/2022 18:10:29	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/01/2022 18:31:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/01/2022 23:43:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/01/2022 00:10:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/01/2022 09:40:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/01/2022 10:02:29	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
04/01/2022 18:48:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/01/2022 03:45:03	Fire	Smoke/condensation	Steam	Hospital (P)
06/01/2022 14:57:46	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
06/01/2022 19:22:55	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/01/2022 22:24:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/01/2022 07:47:10	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/01/2022 23:25:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/01/2022 23:45:00	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
07/01/2022 23:59:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
08/01/2022 07:41:41	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
08/01/2022 08:25:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/01/2022 10:55:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/01/2022 10:42:05	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
09/01/2022 23:37:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/01/2022 04:17:00	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
10/01/2022 09:32:51	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/01/2022 14:49:37	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
11/01/2022 19:27:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/01/2022 13:41:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/01/2022 00:03:39	Fire	Smoke/condensation	Steam	Hospital (P)
13/01/2022 13:37:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/01/2022 13:40:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/01/2022 12:04:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/01/2022 14:05:21	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/01/2022 18:34:18	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/01/2022 13:26:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/01/2022 17:02:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/01/2022 21:35:39	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/01/2022 16:36:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/01/2022 06:21:33	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
20/01/2022 11:51:59	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
20/01/2022 12:54:09	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/01/2022 15:03:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/01/2022 11:23:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/01/2022 19:53:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/01/2022 11:30:50	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
26/01/2022 12:19:06	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
26/01/2022 21:14:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/01/2022 04:43:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/01/2022 11:14:48	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/01/2022 05:07:39	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
29/01/2022 10:50:08	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/01/2022 00:26:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/02/2022 10:51:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/02/2022 13:57:00	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
02/02/2022 00:01:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/02/2022 11:33:54	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/02/2022 02:23:42	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
04/02/2022 16:44:51	Fire alarm due to Apparatus	System: sprinkler	Alarm actuated - Other reason	Hospital (P)
04/02/2022 20:50:36	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/02/2022 08:25:26	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/02/2022 21:42:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/02/2022 17:45:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/02/2022 19:29:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/02/2022 23:27:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/02/2022 10:10:06	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
09/02/2022 14:25:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/02/2022 06:27:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/02/2022 21:17:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/02/2022 17:59:32	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/02/2022 18:52:02	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
15/02/2022 12:27:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
15/02/2022 15:16:23	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
16/02/2022 04:30:13	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/02/2022 05:50:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/02/2022 09:03:31	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
16/02/2022 15:36:34	Good Intent false alarm	Good Intent false alarm	Special Service - Brigade action not required	Hospital (P)
17/02/2022 03:02:51	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
17/02/2022 11:47:27	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/02/2022 12:20:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/02/2022 09:24:32	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
19/02/2022 10:28:40	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/02/2022 10:48:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/02/2022 13:29:37	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
20/02/2022 08:11:08	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/02/2022 06:56:14	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
22/02/2022 12:10:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/02/2022 12:29:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/02/2022 22:32:47	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/02/2022 23:04:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/02/2022 20:27:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/02/2022 00:50:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/02/2022 10:30:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/02/2022 08:53:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/02/2022 21:38:15	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
01/03/2022 07:00:44	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
02/03/2022 01:00:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/03/2022 03:27:32	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/03/2022 14:28:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/03/2022 10:57:25	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
04/03/2022 12:03:42	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
04/03/2022 13:50:56	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
04/03/2022 21:57:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/03/2022 11:28:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
06/03/2022 10:13:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
07/03/2022 14:05:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/03/2022 10:33:05	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/03/2022 02:14:56	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/03/2022 05:28:09	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/03/2022 10:59:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/03/2022 14:49:45	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/03/2022 22:04:17	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
13/03/2022 14:35:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/03/2022 13:22:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
16/03/2022 10:09:57	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/03/2022 14:06:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/03/2022 17:09:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/03/2022 18:53:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/03/2022 20:09:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/03/2022 17:34:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/03/2022 18:55:28	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
19/03/2022 22:23:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/03/2022 01:37:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
20/03/2022 18:33:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/03/2022 15:31:42	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/03/2022 09:21:20	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/03/2022 20:13:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/03/2022 05:39:55	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/03/2022 09:23:02	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
24/03/2022 22:03:25	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/03/2022 02:32:50	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
25/03/2022 05:38:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/03/2022 16:34:55	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
26/03/2022 02:20:05	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
26/03/2022 06:27:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/03/2022 18:45:24	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/03/2022 20:30:28	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
29/03/2022 19:05:20	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
30/03/2022 08:22:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/03/2022 12:52:58	Fire	Burnt toast/food	Toaster/toast	Hospital (P)
31/03/2022 00:38:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/03/2022 09:33:13	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
31/03/2022 11:56:41	Fire alarm due to Apparatus	System: sprinkler	Faulty system	Hospital (P)
31/03/2022 14:35:10	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
31/03/2022 17:33:37	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/03/2022 20:15:10	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
01/04/2022 11:12:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/04/2022 11:09:31	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
02/04/2022 19:53:09	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
04/04/2022 13:01:44	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
05/04/2022 09:41:07	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/04/2022 08:37:26	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/04/2022 18:45:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/04/2022 10:57:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/04/2022 17:24:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/04/2022 13:39:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/04/2022 18:00:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/04/2022 09:18:31	Fire alarm due to Apparatus	External Factors	Smoke from outside (but not a bonfire)	Hospital (P)
09/04/2022 21:05:06	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
10/04/2022 07:36:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/04/2022 08:46:30	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/04/2022 08:31:49	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/04/2022 11:05:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/04/2022 17:20:56	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
13/04/2022 20:48:49	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
14/04/2022 23:09:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/04/2022 07:15:37	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
15/04/2022 07:45:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/04/2022 04:05:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
16/04/2022 04:38:16	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/04/2022 05:01:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/04/2022 06:02:03	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
16/04/2022 07:22:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/04/2022 09:35:23	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/04/2022 16:32:53	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
17/04/2022 00:58:22	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
17/04/2022 11:55:26	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
17/04/2022 15:12:05	Fire	Smell of burning	Overheating appliance	Hospital (P)
20/04/2022 10:48:56	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/04/2022 13:15:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/04/2022 17:57:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2022 15:34:12	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/04/2022 20:36:10	Good Intent false alarm	Good Intent false alarm	Call to special service - No incident at reported location	Hospital (P)
22/04/2022 08:53:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/04/2022 09:58:39	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
22/04/2022 22:14:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/04/2022 11:15:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/04/2022 11:05:36	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
25/04/2022 12:29:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
27/04/2022 13:30:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/04/2022 16:19:45	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
30/04/2022 07:33:15	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/04/2022 08:20:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/05/2022 06:42:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/05/2022 13:34:53	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
02/05/2022 22:37:03	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
03/05/2022 12:05:32	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
04/05/2022 03:52:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/05/2022 15:17:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/05/2022 08:13:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/05/2022 10:27:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
05/05/2022 12:01:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/05/2022 09:13:06	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/05/2022 12:07:35	Fire	Smell of burning	Overheating appliance	Hospital (P)
07/05/2022 03:33:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/05/2022 06:33:52	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/05/2022 11:06:44	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/05/2022 08:29:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/05/2022 16:04:02	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/05/2022 18:50:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/05/2022 10:59:42	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/05/2022 11:49:08	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/05/2022 20:00:37	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
10/05/2022 21:42:23	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/05/2022 08:44:48	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/05/2022 10:57:39	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/05/2022 13:05:39	Fire alarm due to Apparatus	External Factors	Power surge	Hospital (P)
12/05/2022 09:27:09	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/05/2022 08:40:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/05/2022 08:56:33	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/05/2022 05:25:24	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
16/05/2022 02:14:06	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/05/2022 13:34:25	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/05/2022 14:36:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/05/2022 23:49:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/05/2022 01:14:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/05/2022 03:47:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/05/2022 02:09:17	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
19/05/2022 11:28:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/05/2022 11:30:31	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/05/2022 15:39:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/05/2022 18:13:01	Fire alarm due to Apparatus	System: heat	Incorrect positioning	Hospital (P)
20/05/2022 04:05:08	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
20/05/2022 15:36:44	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/05/2022 17:17:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/05/2022 23:37:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/05/2022 00:50:36	Fire alarm due to Apparatus	External Factors	External factor - Other	Hospital (P)
21/05/2022 03:14:31	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/05/2022 19:01:57	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
22/05/2022 01:01:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/05/2022 19:26:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/05/2022 05:42:20	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
23/05/2022 10:09:58	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
23/05/2022 11:19:21	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/05/2022 14:23:42	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/05/2022 15:05:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/05/2022 04:44:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/05/2022 10:07:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
24/05/2022 16:25:27	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/05/2022 19:03:27	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/05/2022 21:33:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
25/05/2022 03:39:46	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
25/05/2022 06:35:20	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/05/2022 08:31:21	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
25/05/2022 09:41:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/05/2022 12:12:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/05/2022 16:13:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/05/2022 12:58:01	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/05/2022 17:12:47	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
28/05/2022 13:06:26	Fire	Smell of burning	Fire elsewhere (not at location)	Hospital (P)
28/05/2022 19:45:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/05/2022 15:01:26	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
30/05/2022 23:39:25	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/05/2022 08:50:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/05/2022 10:01:32	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
31/05/2022 14:55:04	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
01/06/2022 12:06:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/06/2022 12:06:28	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/06/2022 16:42:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/06/2022 00:38:58	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
02/06/2022 23:41:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/06/2022 11:38:26	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
05/06/2022 22:31:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/06/2022 05:03:09	Fire alarm due to Apparatus	System: smoke alarm	Damaged system	Hospital (P)
06/06/2022 14:53:07	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/06/2022 10:06:59	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
07/06/2022 11:13:17	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
07/06/2022 11:35:19	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/06/2022 12:09:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/06/2022 18:41:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/06/2022 08:06:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/06/2022 14:48:23	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
08/06/2022 17:02:23	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/06/2022 21:55:35	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
09/06/2022 23:27:03	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/06/2022 03:17:38	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/06/2022 07:38:40	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/06/2022 11:22:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/06/2022 12:13:43	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/06/2022 13:45:16	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/06/2022 14:15:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/06/2022 21:01:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/06/2022 07:05:26	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/06/2022 08:38:03	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/06/2022 10:17:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/06/2022 20:58:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/06/2022 15:44:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/06/2022 16:23:39	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
15/06/2022 04:03:28	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
15/06/2022 12:22:15	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
15/06/2022 20:16:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/06/2022 08:51:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/06/2022 08:02:46	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/06/2022 11:37:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/06/2022 13:15:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/06/2022 18:51:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/06/2022 22:56:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/06/2022 06:09:11	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
20/06/2022 13:59:17	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/06/2022 17:18:21	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
21/06/2022 10:12:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/06/2022 11:37:57	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
21/06/2022 21:03:09	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
21/06/2022 22:22:50	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/06/2022 23:55:25	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
22/06/2022 08:47:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
22/06/2022 14:29:34	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
22/06/2022 21:16:27	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/06/2022 09:27:48	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/06/2022 11:25:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/06/2022 11:34:39	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/06/2022 20:37:20	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/06/2022 21:08:26	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/06/2022 01:00:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
24/06/2022 07:50:32	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/06/2022 10:05:15	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/06/2022 14:57:17	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
27/06/2022 01:10:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/06/2022 12:43:11	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
27/06/2022 15:45:41	Fire	Burnt toast/food	Other cooking	Hospital (P)
28/06/2022 15:48:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/06/2022 16:06:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/06/2022 18:49:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
01/07/2022 10:50:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
02/07/2022 09:23:46	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
03/07/2022 13:39:27	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
04/07/2022 23:24:07	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
04/07/2022 23:28:00	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/07/2022 16:55:18	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
06/07/2022 21:54:47	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/07/2022 23:43:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
08/07/2022 08:02:08	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/07/2022 21:09:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/07/2022 08:20:50	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
09/07/2022 22:46:23	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/07/2022 13:48:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
11/07/2022 06:46:06	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/07/2022 09:08:18	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/07/2022 14:13:51	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
11/07/2022 20:01:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/07/2022 03:10:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/07/2022 07:04:10	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/07/2022 07:16:21	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/07/2022 08:27:16	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
13/07/2022 09:12:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/07/2022 10:23:08	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/07/2022 12:39:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2022 01:41:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2022 01:59:17	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
14/07/2022 04:05:55	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2022 04:09:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2022 05:05:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/07/2022 07:15:27	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
15/07/2022 03:01:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/07/2022 11:29:41	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
17/07/2022 12:04:30	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
17/07/2022 13:59:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/07/2022 18:14:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/07/2022 17:58:02	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
18/07/2022 18:37:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/07/2022 04:50:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/07/2022 16:11:12	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
20/07/2022 18:31:27	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
21/07/2022 11:26:14	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/07/2022 15:37:41	Good Intent false alarm	Fire	Security/Intruder alarm sounding	Hospital (P)
22/07/2022 22:18:05	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
23/07/2022 02:39:13	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
23/07/2022 22:09:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/07/2022 12:24:54	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
25/07/2022 08:27:35	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
25/07/2022 08:30:34	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/07/2022 09:51:19	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
27/07/2022 02:17:11	Fire alarm due to Apparatus	System: other	Poor maintenance of system	Hospital (P)
27/07/2022 11:04:59	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/07/2022 07:06:16	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2022 14:07:16	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
29/07/2022 17:27:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/07/2022 22:59:48	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/07/2022 01:16:07	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
30/07/2022 04:26:04	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
30/07/2022 15:09:29	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/07/2022 09:19:28	Fire	Smoke/condensation	Controlled burning	Hospital (P)
31/07/2022 14:10:52	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
31/07/2022 16:53:55	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
01/08/2022 01:38:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/08/2022 02:04:24	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/08/2022 09:33:03	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/08/2022 08:34:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/08/2022 12:57:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/08/2022 14:55:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
03/08/2022 20:41:18	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
03/08/2022 21:49:36	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
04/08/2022 02:01:25	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
04/08/2022 13:31:40	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
07/08/2022 09:01:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/08/2022 21:09:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/08/2022 02:27:40	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
09/08/2022 04:00:24	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
10/08/2022 07:00:00	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
10/08/2022 10:39:56	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
11/08/2022 05:44:00	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
11/08/2022 08:23:54	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
11/08/2022 15:27:51	Fire alarm due to Apparatus	System: heat	Faulty system	Hospital (P)
11/08/2022 17:26:52	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
11/08/2022 19:23:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2022 01:00:47	Fire alarm due to Apparatus	System: heat	Damaged system	Hospital (P)
12/08/2022 02:57:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/08/2022 03:27:19	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/08/2022 06:18:32	Good Intent false alarm	Fire	Security/Intruder alarm sounding	Hospital (P)
13/08/2022 08:52:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/08/2022 13:25:02	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
14/08/2022 14:26:36	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
15/08/2022 08:21:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
16/08/2022 12:50:41	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/08/2022 08:19:14	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/08/2022 14:46:46	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
17/08/2022 15:28:40	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
17/08/2022 19:01:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
18/08/2022 07:42:07	Fire alarm due to Apparatus	System: flame	Faulty system	Hospital (P)
18/08/2022 14:11:20	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
18/08/2022 16:56:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/08/2022 19:36:48	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/08/2022 09:53:09	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
20/08/2022 08:10:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/08/2022 09:32:09	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
20/08/2022 10:45:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/08/2022 14:31:50	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/08/2022 17:22:41	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
21/08/2022 07:16:05	Fire	Smell of burning	Overheating light/fitting	Hospital (P)
22/08/2022 18:02:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
22/08/2022 20:46:55	Fire alarm due to Apparatus	System: other	Water intrusion	Hospital (P)
23/08/2022 07:06:53	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/08/2022 16:40:21	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/08/2022 19:53:05	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/08/2022 20:21:22	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
23/08/2022 23:18:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/08/2022 00:39:43	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/08/2022 01:59:07	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
24/08/2022 03:12:06	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/08/2022 07:11:52	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
24/08/2022 13:34:52	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
25/08/2022 00:47:53	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
25/08/2022 09:06:21	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
25/08/2022 21:47:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
25/08/2022 23:54:05	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/08/2022 02:34:35	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/08/2022 03:45:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
27/08/2022 17:25:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
27/08/2022 22:29:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/08/2022 21:39:46	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/08/2022 21:54:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
29/08/2022 18:23:01	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/08/2022 03:37:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/08/2022 22:53:08	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
31/08/2022 13:47:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
31/08/2022 14:08:02	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
01/09/2022 00:19:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
01/09/2022 16:46:54	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
01/09/2022 21:30:58	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
02/09/2022 06:13:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/09/2022 09:22:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/09/2022 06:30:58	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/09/2022 13:55:53	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
06/09/2022 11:41:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/09/2022 15:55:47	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
07/09/2022 02:28:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
07/09/2022 06:59:20	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
07/09/2022 10:23:22	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
07/09/2022 16:50:41	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/09/2022 20:19:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/09/2022 06:27:38	Fire alarm due to Apparatus	System: smoke alarm	Unsuitable equipment	Hospital (P)
08/09/2022 08:03:59	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/09/2022 12:32:40	Fire	Smell of burning	Overheating appliance	Hospital (P)
08/09/2022 12:42:45	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
08/09/2022 21:21:47	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
08/09/2022 21:51:07	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/09/2022 05:42:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/09/2022 07:46:18	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
10/09/2022 08:26:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/09/2022 09:33:40	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
11/09/2022 12:56:30	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
12/09/2022 08:13:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/09/2022 12:30:14	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
13/09/2022 11:06:05	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/09/2022 11:55:23	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/09/2022 07:46:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/09/2022 10:17:49	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/09/2022 16:13:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/09/2022 04:16:40	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/09/2022 08:45:09	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/09/2022 11:22:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/09/2022 19:19:00	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
16/09/2022 17:32:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
17/09/2022 05:48:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/09/2022 23:31:04	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
18/09/2022 07:19:04	Fire alarm due to Apparatus	System: sprinkler	Incorrect positioning	Hospital (P)
18/09/2022 12:04:35	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
19/09/2022 08:07:03	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
19/09/2022 13:09:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/09/2022 01:32:33	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/09/2022 09:45:19	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/09/2022 11:56:28	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
20/09/2022 16:59:13	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/09/2022 17:37:28	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/09/2022 03:51:32	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
21/09/2022 10:32:51	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
22/09/2022 00:38:24	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/09/2022 06:59:10	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
23/09/2022 10:08:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
23/09/2022 10:40:29	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/09/2022 08:08:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
24/09/2022 11:27:57	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/09/2022 07:11:31	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
26/09/2022 11:01:58	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/09/2022 12:05:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/09/2022 17:30:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
26/09/2022 23:07:51	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
28/09/2022 20:16:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
29/09/2022 23:19:11	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/09/2022 11:52:32	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/09/2022 18:23:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/10/2022 00:55:02	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/10/2022 02:52:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/10/2022 07:24:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/10/2022 18:30:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
05/10/2022 09:52:18	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/10/2022 07:29:29	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
06/10/2022 07:32:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/10/2022 09:07:07	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
06/10/2022 09:07:19	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/10/2022 12:54:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
06/10/2022 14:52:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/10/2022 20:45:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/10/2022 23:02:26	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
08/10/2022 03:00:02	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
08/10/2022 08:30:27	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
08/10/2022 13:59:12	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/10/2022 09:25:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/10/2022 02:31:13	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/10/2022 08:52:08	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
12/10/2022 21:33:53	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/10/2022 23:15:28	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)



Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
13/10/2022 11:00:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
14/10/2022 12:44:29	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
14/10/2022 17:04:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/10/2022 11:19:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/10/2022 21:07:25	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
17/10/2022 11:50:49	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
17/10/2022 14:02:30	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
17/10/2022 15:17:32	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/10/2022 18:19:45	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/10/2022 22:57:25	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
18/10/2022 01:13:58	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
18/10/2022 08:20:38	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
19/10/2022 00:17:54	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/10/2022 11:57:00	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
20/10/2022 10:57:33	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
21/10/2022 05:47:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
21/10/2022 23:32:59	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/10/2022 15:21:30	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/10/2022 17:31:51	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
23/10/2022 17:34:49	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
23/10/2022 17:55:43	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
23/10/2022 20:55:42	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/10/2022 13:45:57	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
24/10/2022 16:23:54	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/10/2022 16:46:55	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/10/2022 05:59:16	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
27/10/2022 20:39:22	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/10/2022 06:51:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
28/10/2022 15:52:40	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
28/10/2022 21:42:49	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/10/2022 21:43:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/10/2022 08:48:40	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
29/10/2022 20:10:41	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
29/10/2022 21:45:14	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/10/2022 10:41:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/10/2022 05:04:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
31/10/2022 08:16:14	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
31/10/2022 08:41:25	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
31/10/2022 19:52:29	Fire	Smoke/condensation	Steam	Hospital (P)
31/10/2022 22:10:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
01/11/2022 11:52:06	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/11/2022 01:04:50	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/11/2022 15:03:49	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
02/11/2022 22:56:28	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
02/11/2022 23:49:20	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
03/11/2022 02:26:05	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
03/11/2022 18:58:41	Fire	Smell of burning	Overheating appliance	Hospital (P)
03/11/2022 21:16:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
04/11/2022 08:38:02	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
05/11/2022 00:22:23	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/11/2022 12:14:59	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
06/11/2022 07:44:37	Fire alarm due to Apparatus	Contaminants	System contaminated - Other	Hospital (P)
06/11/2022 09:19:47	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
06/11/2022 16:21:01	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
06/11/2022 17:31:13	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
07/11/2022 12:40:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
08/11/2022 13:46:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
09/11/2022 10:14:00	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
09/11/2022 16:47:59	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/11/2022 09:12:28	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
10/11/2022 15:16:52	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/11/2022 15:41:26	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
10/11/2022 23:51:42	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
11/11/2022 19:24:55	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
12/11/2022 08:30:38	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
12/11/2022 13:40:37	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
13/11/2022 14:47:42	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/11/2022 18:24:17	Good Intent false alarm	Fire	Other reason (inc Smoke Cloak where person called Brigade)	Hospital (P)
13/11/2022 18:24:55	Fire alarm due to Apparatus	System: flame	Poor maintenance of system	Hospital (P)
13/11/2022 19:41:43	Good Intent false alarm	Fire	Call to fire - No incident at reported location	Hospital (P)
14/11/2022 03:17:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
14/11/2022 06:00:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
14/11/2022 16:25:34	Fire alarm due to Apparatus	Contaminants	Thrips/Small insects	Hospital (P)
14/11/2022 21:35:05	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/11/2022 12:48:16	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
15/11/2022 16:42:20	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
16/11/2022 08:16:28	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
16/11/2022 19:03:50	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
17/11/2022 06:21:23	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
17/11/2022 07:15:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
17/11/2022 08:40:44	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/11/2022 08:51:51	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
17/11/2022 13:54:55	Fire alarm due to Apparatus	System: heat	Incorrect positioning	Hospital (P)
18/11/2022 12:01:48	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
19/11/2022 09:05:39	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
19/11/2022 19:37:32	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
21/11/2022 04:10:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
21/11/2022 10:58:18	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/11/2022 20:28:31	Malicious False Alarm	Malicious False Alarm	Malicious actuation of fire alarm call point	Hospital (P)
21/11/2022 23:17:07	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
22/11/2022 06:09:14	Fire	Smoke/condensation	Steam	Hospital (P)
22/11/2022 20:03:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/11/2022 20:22:45	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
22/11/2022 23:03:34	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/11/2022 08:15:25	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/11/2022 08:31:38	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
23/11/2022 20:13:04	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
23/11/2022 22:21:15	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
24/11/2022 05:44:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/11/2022 08:16:46	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
24/11/2022 08:55:10	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
24/11/2022 11:50:31	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
24/11/2022 13:08:47	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
24/11/2022 18:26:45	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
25/11/2022 14:17:53	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/11/2022 08:22:47	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
26/11/2022 18:13:10	Fire	Smell of burning	Overheating appliance	Hospital (P)
26/11/2022 20:42:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
26/11/2022 23:21:40	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/11/2022 21:18:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/11/2022 13:38:06	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
29/11/2022 15:33:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/11/2022 12:19:45	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
30/11/2022 18:46:19	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/11/2022 19:44:38	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
01/12/2022 08:44:59	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
02/12/2022 04:30:37	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
02/12/2022 11:35:51	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
02/12/2022 11:54:27	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
03/12/2022 02:07:05	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
03/12/2022 14:54:12	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
03/12/2022 19:02:25	Fire alarm due to Apparatus	Human	Fire alarm actuated by smoking	Hospital (P)
04/12/2022 01:07:30	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
04/12/2022 02:46:36	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/12/2022 15:07:18	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
05/12/2022 21:47:53	Fire alarm due to Apparatus	System: smoke alarm	Water intrusion	Hospital (P)
06/12/2022 10:01:47	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
06/12/2022 16:43:57	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
07/12/2022 06:14:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
07/12/2022 19:54:26	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
08/12/2022 08:23:25	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
08/12/2022 14:38:38	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
09/12/2022 16:30:42	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
09/12/2022 23:30:11	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
10/12/2022 11:46:34	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
10/12/2022 13:19:46	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
10/12/2022 15:08:43	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
11/12/2022 12:19:33	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
12/12/2022 23:32:51	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
13/12/2022 09:35:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
13/12/2022 12:22:58	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
13/12/2022 17:39:36	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
13/12/2022 19:38:55	Malicious False Alarm	Malicious False Alarm	Malicious call to a fire - false alarm	Hospital (P)
13/12/2022 21:39:01	Fire alarm due to Apparatus	Human	Fire alarm actuating - human reason - other	Hospital (P)
14/12/2022 13:03:45	Fire alarm due to Apparatus	System: heat	Poor maintenance of system	Hospital (P)
14/12/2022 14:51:05	Fire	Smoke/condensation	Steam	Hospital (P)
14/12/2022 16:27:54	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
15/12/2022 04:49:59	Fire alarm due to Apparatus	Contaminants	Chemicals/aerosols	Hospital (P)
15/12/2022 12:51:04	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
16/12/2022 05:45:25	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
16/12/2022 19:27:02	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
16/12/2022 21:06:40	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

Time of Call	Grand Parent False Alarm Reason	Parent False Alarm Reason	False Alarm Reason	Property Type
17/12/2022 20:21:03	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
19/12/2022 09:34:43	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
19/12/2022 14:43:56	Fire alarm due to Apparatus	System: smoke alarm	Alarm actuated - Other reason	Hospital (P)
19/12/2022 16:51:11	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2022 08:25:59	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2022 09:54:22	Fire alarm due to Apparatus	Contaminants	Dust	Hospital (P)
20/12/2022 15:21:43	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
20/12/2022 15:48:19	Fire alarm due to Apparatus	Human	Testing of fire alarm system	Hospital (P)
21/12/2022 22:34:33	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
22/12/2022 10:10:44	Fire alarm due to Apparatus	System: other	Faulty system	Hospital (P)
23/12/2022 19:50:37	Fire alarm due to Apparatus	Contaminants	Steam	Hospital (P)
26/12/2022 19:44:45	Fire	Burnt toast/food	Other cooking	Hospital (P)
27/12/2022 12:06:56	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
27/12/2022 18:13:47	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
28/12/2022 04:27:21	Fire alarm due to Apparatus	System: smoke alarm	Faulty system	Hospital (P)
28/12/2022 14:36:42	Fire alarm due to Apparatus	System: smoke alarm	Poor maintenance of system	Hospital (P)
28/12/2022 20:18:58	Fire alarm due to Apparatus	Fire alarm due to Apparatus	Unknown	Hospital (P)
29/12/2022 10:59:37	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)
30/12/2022 00:32:58	Fire alarm due to Apparatus	Human	Fire alarm actuated by cooking/burnt toast	Hospital (P)
30/12/2022 14:52:23	Fire alarm due to Apparatus	Human	Accidental/Careless actuation of fire alarm call point	Hospital (P)

We have dealt with your request under the Freedom of Information Act 2000. For more information about this process please see the guidance we publish about making a request [on our website](#).