

Freedom of Information request reference number: 7691.1

Date of response: 4 August 2023

Request:

Pioneer Point Ilford IG1 2FS

We are attempting to track down the original LFB Sign Off for when the building was completed in 2011.

Our current Fire Risk Assessment picks up the fact that the Fire Fighting Stairwell Screens to each floor are to be 2 Hr Screens, whereas we have 1 Hr Screens installed.

From the Fire Strategy document that we have in place, it appears that mitigation has been agreed on the level of Fire Integrity required – please see highlighted section in the email below.

We would need to see evidence of the agreed mitigation & signed off by LFB if at all possible please

Response:

I have checked the fire safety records we hold for the property Pioneer Point Ilford IG1 2FS

We do not hold a copy of the building consultation for 2011 our records only go back to 2013/2014.

I am sorry this is not the response you were hoping for.

We have dealt with your request under the Freedom of Information Act 2000. For more information about this process please see the guidance we publish about making a request [on our website](#)